

IC9452

## INFORMATION CIRCULAR/2000

# An Underground Coal Mine Fire Preparedness and Response Checklist: The Instrument





U.S. DEPARTMENT OF HEALTH AND HUMAN SERVICES Public Health Service Centers for Disease Control and Prevention National Institute for Occupational Safety and Health **Information Circular 9452** 

# An Underground Coal Mine Fire Preparedness and Response Checklist: The Instrument

By Ronald S. Conti, Linda L. Chasko, Charles P. Lazzara, Ph.D., and Gary Braselton

U.S. DEPARTMENT OF HEALTH AND HUMAN SERVICES Public Health Service Centers for Disease Control and Prevention National Institute for Occupational Safety and Health Pittsburgh Research Laboratory Pittsburgh, PA

August 2000

International Standard Serial Number ISSN 1066-5552

## CONTENTS

## Page

Abstract
Background
Underground coal mine fire preparedness and response checklist
Water system
High-expansion foam
Fire extinguishers
Fire stations
Automatic fire detection and suppression systems
Coal and other combustible materials
Self-contained self-rescuer
First responders, fire brigades, and mine rescue
Other issues
Generic checklists
Summary
Acknowledgments
References
Appendix A.—NIOSH underground coal mine fire preparedness and response checklist
Water supply
Hoses and nozzles
Foam firefighting equipment
Fire extinguishers
Fire stations
Detection systems
Suppression systems
Ventilation
Combustible materials underground
Housekeeping
Evacuation plans
Self-contained self-rescuers
First responders to fire
Fire brigades
Mine rescue
Specialized equipment
Appendix B.—Examples of inspection, maintenance, and general housekeeping checklists and procedures
Annual hydrant checks
Annual fire hose checks
Annual fire hose tests
Monthly checks on foam generator
Brattice curtain for foam generator
Monthly surface fire extinguisher checklist
Biannual underground fire extinguisher checklist
6-month fire extinguisher inspection
Extinguisher mounting locations
Trailer-mounted Ansul 150C fire extinguishers
Firefighting equipment fire audit report
First-aid sumplies (evample 1)
First-aid supplies (example 2)
Emergency material skids
Fire audit form
Surface fire brigade trailer contents
Underground fire brigade skid contents
Materials list for mina rescue amerganey
Safety trailer locations

## **CONTENTS**–Continued

		-
	Fire protection and firefighting standards	81
	Fire prevention equipment checklist	84
	Functional test of mine monitoring systems	86
	Weekly Conspec system functional test	87
	Mine monitor inspection report	88
	Conspec emergency communication center activity log	89
	Conspec room callout log	90
	Cutting/welding permit (example 1)	91
	Cutting/welding permit (example 2)	92
	Specifications for slope water line	94
	Specifications for foregring and confronzing locations	05
	Suppression system for freezing and nonneezing locations	95 07
	Suppression system	21
	Annual functional test of the fire suppression at beit drives	98
	Drawing of a typical water lance	99
	Individual work hazard assessment	100
	Beltline inspection checklist	102
	SCSR check sheet	103
	Daily SCSR examinations	104
Aj	ppendix C.—Examples of response plans and training programs	105
	Mine emergency operation plan	105
	Emergency response (example 1)	113
	Emergency response (example 2)	116
	Emergency response (fire detection for two-entry system)	119
	Firefighting and evacuation plan	125
	Firefighting and evacuation plan	133
	Proceedure and duties for fire	120
	Specific individual duty labels in the event of a fire	139
	Specific individual duty labels in the event of a life	140
	Fine drill simulations	141
	Fire drill simulations	142
	Selection procedures for new emergency response members	145
	Requirements for emergency response teams	147
	Training of fire brigade members	149
	Standard operating procedures for fire attack of the fire brigade	150
	Donning procedures for PA-80 SCBA	151

## ILLUSTRATIONS

1.	1,000,000-gal surface water storage tank at an underground mine	3
2.	Measuring the throw distance of water hose	3
3.	Inspection of an underground fire hydrant	4
4.	Underground storage of fire water hose in barrel	4
5.	Underground storage of fire water hose in a rack	4
6.	Erecting a typical mine stopping for a high-expansion foam generator	4
7.	Inflatable feed-tube partition in the Lake Lynn Experimental Mine	4
8.	Dry-chemical portable fire extinguisher mounted on the rib	5
9.	Dry-chemical wheeled fire extinguisher	5
10.	Rock dust stored in plastic bags	6
11.	Rock dust storage unprotected	6
12.	Fire trailer located on the surface of an underground mine	6
13.	CO fire sensor mounted in mine entry	6
14.	Sprinkler system installed in mine entry	7
15.	Underground oil storage area	7
16.	Improper storage of underground trash	7
17.	Mine rescue teams fighting a conveyor belt fire at Lake Lynn Laboratory	8

## UNIT OF MEASURE ABBREVIATIONS USED IN THIS REPORT

Btu	British thermal unit	m/sec	meter(s) per second
fpm	foot (feet) per minute	mg/L	milligram(s) per liter
ft	foot (feet)	min	minute(s)
ft/min	foot (feet) per minute	oz	ounce(s)
ft <sup>3</sup> /min	cubic foot (feet) per minute	ppm	part(s) per million
gal	gallon(s)	psi	pound(s) (force) per square inch
gpm	gallon(s) per minute	psig	pound(s) (force) per square inch, gauge
hr	hour(s)	sec	second(s)
in	inch(es)	yd	yard(s)
lb	pound(s)	EF	degrees Fahrenheit

### AN UNDERGROUND COAL MINE FIRE PREPAREDNESS AND RESPONSE CHECKLIST: THE INSTRUMENT

By Ronald S. Conti,<sup>1</sup> Linda L. Chasko,<sup>2</sup> Charles P. Lazzara, Ph.D.<sup>3</sup> and Gary Braselton<sup>4</sup>

#### ABSTRACT

Preparedness is an important element of any underground mine's strategic plan in dealing with an unexpected event, such as a fire. A fully implemented fire preparedness and response plan is essential in reducing the probability and seriousness of a mine fire. This report describes the development of an underground coal mine fire preparedness and response checklist (MFPRC). The checklist is a data collection instrument for profiling both the fire prevention and response capabilities of a mine site and usually requires 3 to 4 days to complete. The checklist encompasses conditions, procedures, and equipment that have frequently been identified as the primary or contributing causes of underground coal mine fires. At least 1 day is needed underground to evaluate the water system. This entails measurements of waterflows and pressures at fire hydrants, and water throw distances of fire hose and nozzles at several locations (mains and branch lines). A few of the other topics that are discussed with mine personnel include detection and suppression systems, combustible materials, mine rescue and fire brigades, and firefighting equipment.

The MFPRC was developed by the National Institute for Occupational Safety and Health (NIOSH), Pittsburgh Research Laboratory. Under a Cooperative Research and Development Agreement (CRADA) with Cyprus Amax, Twentymile Coal Co. (Oak Creek, CO), the checklist was field tested and further refined. Additional field tests were conducted at several other operating coal mines.

<sup>&</sup>lt;sup>1</sup> Fire prevention engineer, Pittsburgh Research Laboratory, National Institute for Occupational Safety and Health, Pittsburgh, PA.

<sup>&</sup>lt;sup>2</sup> Physical science technician, Pittsburgh Research Laboratory, National Institute for Occupational Safety and Health, Pittsburgh, PA. <sup>3</sup> Research chemist, Pittsburgh Research Laboratory, National Institute for Occupational Safety and Health, Pittsburgh, PA.

A contraction of the second of

<sup>&</sup>lt;sup>4</sup> Safety trainer, Twentymile Coal Mine, Oak Creek, CO.

#### BACKGROUND

Fires are still too common an occurrence in the mining industry. Statistics from the Mine Safety and Health Administration (MSHA)<sup>5</sup> indicate that 153 reportable fires (i.e., fires lasting more than 30 min after discovery or causing injury) occurred at underground coal mines from 1990 to 1999 in the United States, causing 1 fatality and 46 injuries. A significantly higher number of unreportable fires are believed to have occurred. A recent fire happened on November 25, 1998, at Cyprus Plateau Mining Corp.'s Willow Creek underground mine near Price, UT, during coal production. Forty-five miners evacuated. The mine was sealed, and inert gas was injected into the fire area. Mine rescue teams entered the sealed mine on December 9, 1998, to initiate recovery operations. Another fire occurred on January 26, 1999, at Oxbow Mining, Inc.'s Sanborn Creek underground coal mine near Somerset, CO. All of the miners were evacuated, the mine was temporarily sealed, and water was pumped into the mine through a borehole to inundate the suspected fire area. Historically, mine fires have caused fatalities, injuries, and economic losses totaling hundreds of millions of dollars. One goal of the National Institute for Occupational Safety and Health's (NIOSH) Pittsburgh Research Laboratory (PRL) is to enhance the safety of the mine worker by preventing disasters caused by fires and explosions.

The remote nature of underground mining requires workers at all positions within the organization to maintain higher skill levels in emergency response compared with workers in many other industries. Traditional work organizations can, in greater part, rely on professional, full-time, expert community services, and specialists to assist in the response to fire, rescue, and medicalemergencies. For example, smaller cities and towns have volunteer fire departments that are highly capable. The issue of measuring fire preparedness for the individual mine site is critical for predicting the response (including elements of evacuation and firefighting) in case of an underground fire.

Fire is a major concern for those who work underground. A mine fire can occur at any time and often results in a partial or total evacuation of mine personnel. Therefore, a workforce that is well trained to prevent, detect, and fight a fire is important. It is also paramount for miners to maintain and know their escape routes. However, a study by Vaught et al. [1996] of the underground preparedness of miners at seven underground coal mines showed that only 8% of the miners were satisfied with the firefighting training they were receiving. Some of these miners called for less complacency and more involvement by the workers. Out of 214 miners surveyed, 38% reported that they were notified sometime during their mining career to evacuate the mine because of a fire, and 70% were involved in at least 1 firefighting incident.

The success of safely controlling and extinguishing an incipient mine fire depends on several factors, such as an awareness of the fire hazards, early detection, availability of effective firefighting equipment, quick response time, and trained firefighters. If a coal mine fire cannot be contained by direct firefighting methods within a few hours after discovery, the chances of successfully extinguishing the fire without sealing part of the mine or the entire mine are greatly diminished. Many mine operators and workers are not aware of how quickly mine fires can spread, have little knowledge of the magnitude of a detectable fire, and lack experience in the proper selection and use of modern firefighting equipment. Information on the latest mine fire detection, alarm, and extinguishing technologies, and firefighting strategies may be difficult to obtain. Such equipment and techniques could significantly improve the success rate of safe firefighting operations and reduce the risk and occurrence of severe mine fires.

Fire research conducted by the former U.S. Bureau of Mines (USBM) and actual mine fires have shown that fires can spread very rapidly. For example, large-scale fire gallery experiments have shown that conveyor belt fires can propagate at rates greater than 0.10 m/sec (20 fpm) [Lazzara and Perzak 1990]. Still, many in the mining industry believe that fire-resistant belting will not burn. Modern fire detection and firefighting equipment, although available, is not often found in underground mines. Longer detection times result when fire sensors with slow response times are employed [Conti and Litton 1992, 1993; Morrow and Litton 1992]. Often, mine fires grow out of control due to poor planning, inoperative detection systems, inadequate water supplies, inappropriate firefighting equipment, broken water lines, failed suppression systems, and improper personal protective equipment.

Mitchell [1996] states that "the best facilities and equipment can never compensate for poor preparation." A large part of mine fire preparedness is worker capability, experience, motivation, and training, along with a strong commitment by management. Facilities and programs for mine personnel to learn about the hazards of mine fires, evaluate modern fire detection and firefighting equipment and technologies, and observe the proper methods to combat mine fires are lacking. Mine fire application seminars and briefings, sponsored by MSHA at the National Mine Health and Safety Academy [Moser 1993] and conducted by NIOSH at PRL's Lake Lynn Laboratory,<sup>6</sup> are positive steps. Conti [1994] suggested that increasing the mining industry's awareness of the dangers of underground mine fires and conducting periodic fire audits with a well-organized checklist could reduce the probability of a major fire and improve the current state of fire preparedness.

<sup>&</sup>lt;sup>5</sup>Mine fire statistics were obtained from MSHA's Denver Safety and Health Technology Center, Injury and Employment Information Branch, Denver, CO.

<sup>&</sup>lt;sup>6</sup>PRL conducts open industry briefings on mine fire preparedness to enhance the mining industry's awareness of the dangers of underground mine fires and convey research findings on the latest methods for detection, control, response, and extinguishment of mine fires.

#### UNDERGROUND COAL MINE FIRE PREPAREDNESS AND RESPONSE CHECKLIST

The underground coal mine fire preparedness and response checklist (MFPRC) (appendix A) is a data collection instrument used to profile both the fire prevention and response capabilities of a mine site. This instrument can be used as an aid in determining how well the mine meets certain portions of the minimum requirements specified by 30 CFR or exceeds them. Under a Cooperative Research and Development Agreement (CRADA) with Twentymile Coal Co., Oak Creek, CO, the checklist was field tested and further refined. Additional field tests were conducted at several other operating coal mines. The checklist encompasses conditions, procedures, and equipment that have frequently been identified as the primary or contributing causes of underground coal mine fires. The checklist usually requires 3 to 4 days at the mine site to complete. At least 1 day is needed underground to evaluate the water system. Other topics that are discussed with mine personnel include detection and suppression systems, combustible materials, mine rescue and fire brigades, and firefighting equipment. Tables are included in the MFPRC to tabulate the data. The checklist provides an instant picture of the preparedness of the mine to prevent or respond to a fire and identifies areas that need to be strengthened. After the MFPRC is completed at a mine site, a data summary is prepared by NIOSH personnel and forwarded to the appropriate mine officials, or the summary can be compiled by the operator.

#### WATER SYSTEM

In the event of an underground coal mine fire, it is critical to extinguish the fire in its early stages. Any delay in initiating firefighting activities can result in an uncontrolled fire. Water is an effective and economical fire extinguishing agent, and it is usually abundant and easily pumped. However, water may not always be available in sufficient quantity to fight a large fire. Considerable planning should be given to adequate water supplies, water lines, hydrants and their locations, water pressures, types and sizes of nozzles, and an appropriate hands-on training program. It is crucial that an adequate amount of water hose or line be readily available in a mine and that all fittings are standardized to ensure equipment compatibility. Preparations should be made to extend water lines in case a fire starts in a remote section of the mine.

The MFPRC requires measurements of waterflows and pressures at fire hydrants and water throw distances of the fire hose and nozzles at several underground locations (main and branch lines). The quantity and quality of the water available for firefighting are determined and storage facilities examined. A surface water storage tank at an underground mine is shown in figure 1. Figure 2 illustrates testing of the throw distance of a water hose. Fire hydrant locations and markings are checked, as well as procedures to store and test water hose and nozzles. The inspection of an underground fire hydrant is shown in figure 3. The underground storage of water hose in a barrel and in a rack is shown in figures 4 and 5, respectively. The MFPRC includes tables to record the names of main and branch water lines, pipe sizes and schedules, type of material, and safe operating pressures. Measured waterflow and pressures at fire hydrants are also noted. A fire nozzle table lists the total number, type, and pressure rating of nozzles on the surface and underground. A fire hose table identifies the location of water hoses, both on the surface and underground, and includes total length, size, thread type, material, and pressure ratings. Another table lists the throw distance of the water stream at various locations with respect to entry height, water hose size, and type of water nozzle.

#### **HIGH-EXPANSION FOAM**

When an underground fire cannot be directly attacked due to heat, smoke, or hazardous roof conditions, high-expansion foam may be one way to remotely quench the fire. Foam is a convenient means of conveying water to a fire. It suppresses/



Figure 1.—1,000,000-gal surface water storage tank at an underground mine.



Figure 3.—Inspection of an underground fire hydrant.



Figure 2.—Measuring the throw distance of water hose.



Figure 4.—Underground storage of fire water hose in barrel.



Figure 5.—Underground storage of fire water hose in a rack.

extinguishes a fire by cooling the fire, diluting the oxygen concentration through the production of steam, and restricting air currents to the fire and radiant energy from the burning fuel. The foam can also reduce the spread of the fire by covering combustibles near the fire. Before a foam system is implemented, the mine operator should consider the training and resources needed to effectively use foam. Additional information on the use of foam for fighting underground coal mine fires can be found in the report by Conti [1994]. The MFPRC includes tables to record the various types of firefighting foam generators and foam concentrates on hand, including their locations, foam expansion ratio, and quantity of foam concentrates. Once the equipment and supplies are purchased, a plan must be developed for using foam in the mine. Figure 6 illustrates the building of a typical mine stopping for use with a foam generator. An inflatable feed-tube partition [Conti 1995; Conti et al. 1998a] interfaced with a high-expansion foam generator s h o w n i n figure 7. Foam i s



Figure 6.—Erecting a typical mine stopping for a highexpansion foam generator.



Figure 7.—Inflatable feed-tube partition in the Lake Lynn Experimental Mine.

equipment should be compatible with the mine water system with regard to water quality, pressure, and fittings. When using foam or any other means of extinguishment, the mine operator should have an organized strategy for fast response and a group of well-trained miners ready for an emergency situation. The mine should also have periodic drills to test the effectiveness of the firefighting plan.

#### FIRE EXTINGUISHERS

Time is a critical factor when using a fire extinguisher in any fire situation. Two or three seconds can mean the difference between a successful fire extinguishment or disaster. Portable, multipurpose dry-chemical-type fire extinguishers are placed in strategic locations throughout the coal mine, such as working sections, electrical installations, oil storage stations, and on diesel-powered equipment. Extinguishers must be examined every 6 months to ensure that they have not been moved, are visible and accessible, have intact seals, and have no apparent damage or other obvious defects. Sometimes, because of an inadequate maintenance program or an inexperienced operator, a fire extinguisher fails to operate or to extinguish the fire.

A study to determine the reliability of dry-powder, handportable fire extinguishers in the mining industry was conducted by Allen Corp. of America for the USBM [Baker et al. 1981]. Of the 151 cartridge-type and stored-pressure-type extinguishers tested at underground coal mines, 18 (12%) failed to operate properly. The predominant failure causes were related to unreported discharging, improper maintenance, and neglect of environmental effects.

Extinguishers may not be handled until an emergency occurs; during this period, the dry chemical can settle and compact. This phenomenon is known as packing and is dependent on the particle size distribution of the dry-chemical agent. Packing will be more severe if the particle size difference is large and is most likely to occur if the extinguisher is stored vertically and subject to vibration. Caking occurs when the drychemical agent is contaminated by moisture. The moisture chemically reacts with the dry chemical and the individual particles adhere to each other, forming lumps. Caking and packing in dry-chemical extinguishers can affect performance. One recently visited coal mine had recurring problems with clogging of the elbow that connects the body of the extinguisher to the discharge hose.

Two types of dry-chemical fire extinguishers used underground are shown in figures 8 and 9. The MFPRC includes a table to identify the location and sizes of all fire extinguishers stored underground and on the surface. The table includes the total number and whether the extinguishers are hand-portable, wheeled, or skid-mounted. An essential element in any fire safety program is adequate hands-on training in the use and recharging of fire extinguishers.

In addition, rock dust is stored in bags, as shown in figures 10 and 11, at various underground locations to fight fires. It is important that the rock dust be protected from mois-

ture to prevent caking.



Figure 8.—Dry-chemical portable fire extinguisher mounted on the rib.



Figure 9.—Dry-chemical wheeled fire extinguisher.

#### **FIRE STATIONS**

Fire stations include cars, houses, trailers, boxes, and sleds that can transport personnel and equipment to the site of the fire. Figure 12 shows a fire trailer located on the surface of an underground coal mine. The stations must be easily transported to the fire area and be equipped with up-to-date firefighting equipment, tools, supplies, first-aid kits, and personal protective equipment such as bunker gear, including self-contained breathing apparatus (SCBAs). The stations should be inspected regularly.

Figure 10.—Rock dust stored in plastic bags.









Figure 12.—Fire trailer located on the surface of an underground mine.

#### UTOMATIC FIRE DETECTION AND SUPPRESSION SYSTEMS

The early and reliable detection of underground fires is essential to ensure sufficient time to safely evacuate the miners and to extinguish the fire before it spreads. Temperature, carbon monoxide (CO), and smoke sensors can be used to detect underground coal mine fires. Smoke and CO sensors can detect a fire in its smoldering phase, before flames develop, depending on the production rate of smoke or CO by the smoldering fuel and the quantity of air flowing in the mine entry. The MFPRC includes a table to record the types of sensors used, their location, total number, spacing, and vertical position from the mine floor. Any problems with false or nuisance alarms are noted, and procedures for training personnel responsible for monitoring, testing, and calibrating the detection system are reviewed. A CO sensor mounted in an entry is shown in figure 13.

Automatic fire suppression systems used in underground coal mines include water deluge, water sprinkler, high-expansion foam, and dry-chemical. Figure 14 shows a sprinkler system mounted in a conveyor belt entry.

The MFPRC includes a table to record the type of system employed and its location. The procedures used to test and maintain the systems are reviewed. If water barriers (walls of water) are installed in mine entries, another table is provided to list their location, spacing, activation temperature, number of nozzles, and waterflow.

#### COAL AND OTHER COMBUSTIBLE MATERIALS

In an underground coal mine, the coal is virtually an unlimited fuel supply. The most serious mine fires occurred when the coal ignited and burned. The MFPRC addresses which



Figure 13.—CO fire sensor mounted in mine entry.



Figure 14.—Sprinkler system installed in mine entry.

coalbed is being mined and several coal characteristics that can influence its combustibility, including rank, volatility, and ash content. In general, coals of lower rank have a greater selfheating tendency; high-volatile coals spread flame more readily. Any occurrences of spontaneous combustion underground or on the surface in storage piles or silos are noted.

The mining operation requires the use and underground storage of combustible materials. These include fire-resistant conveyor belting, ventilation tubing, electrical cable, and brattice cloth, as well as oil and grease, diesel fuel, wood timbers, etc. It is important to realize that fire-resistant materials can ignite and burn. For example, fire-resistant conveyor belting has been shown to rapidly propagate flame and burn in large-scale tests [Lazzara and Perzak 1990] and in actual mine fires [Strahin et al. 1990]. The MFPRC includes tables to record the quantity and characteristics of the conveyor belting and other combustibles used and stored underground. For conveyor belting, the type (rubber or polyvinyl chloride), width, thickness, length, location, and MSHA fire-resistant approval number are recorded. The type, diameter, wall thickness, and MSHA fireresistant approval number of rigid ventilation ducting are also noted. The total quantity of each combustible material, toxic hazard (low, medium, high) due to burning, and any special precautions beyond those required by Federal regulations are listed. An underground oil storage area is shown in figure 15; a trash storage area is shown in figure 16.

#### SELF-CONTAINED SELF-RESCUER

Federal regulations require that the mine operator make available to each miner and authorized visitors an approved selfrescuer device(s) that is adequate to protect a person for 1 hr or longer. The MFPRC addresses the type and model of the selfcontained self-rescuer (SCSR) used at the mine, the number of units stored underground and on the surface and their locations, and how often SCSR refresher training is conducted. The procedures for inspecting the units for damage and removing units with expired service life are reviewed. Any problems that the mine has experienced with SCSRs are noted.



Figure 15.—Underground oil storage area.



Figure 16.—Improper storage of underground trash.

#### FIRST RESPONDERS, FIRE BRIGADES, AND MINE RESCUE

If a small fire is discovered by a miner with limited training in extinguishing fires, the fire may continue to grow before trained personnel arrive on the scene. First responders are the first persons to initiate firefighting. It is important that these miners be properly trained in the use of fire extinguishers and water hoses and in firefighting procedures. They should also know how to immediately and effectively communicate information about the emergency to other miners and key personnel so that they are aware of the situation.

Underground fire brigades or firefighters and mine rescue teams are important elements in any mine's emergency response plan. Fire brigades are composed of specially trained and equipped miners that work at the mine site and can rapidly respond to a fire. Mine operators most often rely on mine rescue teams to save lives during an underground emergency, such as a fire, explosion, roof fall, or water innundation. It is extremely important that team members be provided with adequate exploration equipment and that training simulations<sup>7</sup> be conducted in a realistic manner [Conti et al. 1998b; Conti and Weiss 1998; Conti et al. 1999]. Figure 17 shows rescue team members fighting a conveyor belt fire in the surface fire gallery at Lake Lynn Laboratory. The MFPRC examines the types of firefighting training conducted. A series of questions is also presented that deal with emergency response plans and duties for miners during firefighting and evacuation. Appendix C includes an example of an emergency response plan and a mine fire training program divided into three areas: basic fire training for all miners, intermediate fire training for fire brigades/mine rescue.

#### **OTHER ISSUES**

Other issues addressed by the MFPRC include ventilation, housekeeping, evacuation plans, and specialized equipment. Ventilation plans and ventilation training drills for various fires that could occur in the mine are addressed. The housekeeping section focuses on the removal and proper disposal of batteries, hazardous waste, and excessive coal dust accumulations. Under evacuation plans, the maintenance and identification of escapeways and how often miners walk the entire escapeway are discussed. The specialized equipment section deals with turnout gear, SCBAs, specialized fire warning systems, and motion sensors for firefighters and mine rescue teams.

#### **GENERIC CHECKLISTS**

Some mines have already developed extensive checklists and procedures on specific topics to improve their state of preparedness. MSHA reported that more than 20% of belt entry fires during 1970-88 were caused by welding/cutting operations [Luzik 1991]. To address this issue, some mines require a hot



Figure 17.—Mine rescue teams fighting a conveyor belt fire at Lake Lynn Laboratory.

work permit before any welding or cutting operations are done (see appendix B, "Cutting/Welding Permit," examples 1 and 2). This permit requires certain safety checks before and after the planned maintenance activity. Each permit is monitored by a communications coordinator. Another way to decrease the probability of a fire in a conveyor belt drive area due to coal dust accumulations, defective equipment, etc., is to have beltline checklist inspections. The checklist requires the examiners to look for potential problem areas and available safety equipment. Some mines cover the total belt drive area (roof, ribs, and floor) with noncombustible material and hose down the area with water once per shift.

Appendix B contains 34 generic examples of checklists and safety procedures that can be used by a mine. These include procedures to conduct annual fire hydrant and fire hose checks; semiannual inspections of fire extinguishers and a monthly checklist for high-expansion foam generators; first-aid supplies for fire cars or safety trailers, and an emergency material skid; and functional tests of mine monitoring and fire suppression systems.

#### SUMMARY

Preparedness is an essential element of any underground mine's strategic plan in dealing with an unexpected fire. It is important that the fire be detected in the incipient stage and that well trained and fully equipped miners respond during that crucial period. Time is a critical factor, and any delay may mean serious injuries and the loss of the mine.

The NIOSH-developed underground coal mine fire preparedness and response checklist is a data collection instrument for determining both the fire prevention and res p o n s e near Fairchance, PA. Additionally, MSHA's National Mine Health and Safety Academy near Beckley, WV, provides training for first responders and mine rescue teams.

<sup>&</sup>lt;sup>7</sup>Mine rescue team training is conducted at NIOSH-PRL's Safety Research Coal Mine at Bruceton, PA, and Lake Lynn Experimental Mine

capabilities at an underground coal mine. It encompasses conditions, procedures, and equipment that have frequently been the primary or contributing cause of underground coal mine fires. Areas that need to be strengthened are identified.

Current NIOSH research is aimed at further refinement and field testing of the MFPRC. A similar checklist for metal/nonmetal mines is currently being developed. Mines participating in this study can have their strengths and weaknesses defined. In addition, there is less chance that problem areas might go undiscovered and not addressed. It also gives miners a chance to share their experiences and gain from the experiences of others. The checklist can also be used as a training aid for the mine, e.g., to show miners and new hires how to check water pressures at fire

MFPRC data, and the program would rate the effectiveness of their mine fire preparedness and response program. The highest anticipated rating would be attained by a mine that matched all or most of the requirements specified for a model mine by a group of experts. Recommendations to improve the state of preparedness would be listed. hydrants or properly store and use a fire hose. The completed checklist gives the mine an instant picture of its fire preparedness and response capabilities. In a subsequent report, the data collected at the mines participating in this study will be analyzed.

An interactive computer program is also being considered for development. Mine personnel would enter the requested

#### ACKNOWLEDGMENTS

The authors thank the following individuals at the NIOSH Pittsburgh Research Laboratory for their contributions: William J. Wiehagen, Industrial Engineer, Robert W. Noll, Physical Science Aide, and the following Twentymile Coal Co. employees for their assistance during the initial field testing of the checklist: Earl Almond, Rolland Barney, Dwaine Chesser, Jerry Delay, John Garcia, Jim Grant, Andy Gustafson, David Hahn, Butch Krump, Lee Norris, Clarence Reed, Dallas Reed, Alan Selch, and Rory Wilson, Fire Brigade/Mine Rescue Team Members; Daryl Firestone and Jim Pogline, Safety Department; and R. Lincoln Derick, Technical Safety Manager. The authors also thank mine personnel from Arch of Illinois, Energy West Mining Co., MAPCO Coal, Inc., and Monterey Coal Co., a division of Exxon, who participated in the field testing.

#### REFERENCES

Baker RM, McDonald LB, Reid G, Duncan C [1981]. Reliability of hand-portable fire extinguishers in the mineral industry. Alexandria, VA: Allen Corp. of America. U.S. Bureau of Mines contract No. H0292011.

Conti RS [1994]. Firefighting resources and fire preparedness for underground coal mines. Pittsburgh, PA: U.S. Department of the Interior, Bureau of Mines, IC 9410.

Conti RS [1995]. Inflatable partitions for high-expansion foam generators. Min Eng 47(6):561-566.

Conti RS, Litton CD [1992]. Response of underground fire sensors: an evaluation. Pittsburgh, PA: U.S. Department of the Interior, Bureau of Mines, RI 9412.

Conti RS, Litton CD [1993]. Effects of stratification on carbon monoxide levels from mine fires. In: Proceedings of the Sixth U.S. Mine Ventilation Symposium. Littleton, CO: Society for Mining, Metallurgy, and Exploration, Inc., pp. 489-494.

Conti RS, Weiss ES [1998]. Inflatable devices for combating underground mine fires. In: Proceedings of Minesafe International 1998. University of Witwatersrand, Republic of South Africa, pp. 388-393.

Conti RS, Chasko LL, Cool JD [1999]. An overview of technology

and training simulations for mine rescue teams. In: Proceedings of the 28th International Conference of Safety in Mines Research Institutes (Sinaia, Romania). Vol. II, pp. 521-538.

Conti RS, Chasko LL, Pro RW [1998a]. Combating mine fires with the aid of inflatable devices. In: Proceedings of the Second International Conference on Fire Research and Engineering. Gaithersburg, MD: U.S. Department of Commerce, National Institute of Standards and Technology, pp. 441-449.

Conti RS, Chasko LL, Stowinsky LD [1998b]. Mine rescue training simulations and technology. In: Proceedings of The International Emergency Management Society (TIEMS) Conference 1998, pp. 453-464.

Lazzara CP, Perzak FJ [1990]. Conveyor belt flammability studies. In: Proceedings of the 21st Annual Institute on Coal Mining Health, Safety, and Research (Blacksburg, VA, August 28-30, 1990), pp. 119-129.

Luzik SJ [1991]. Mine fire prevention response strategies. Presented at the Annual Joint Meeting of SME/PCMIA, Meadowlands, PA, October 31, 1991.

Mitchell DW [1996]. Mine fires: prevention, detection, fighting. Chicago, IL: Maclean Hunter Publishing Co.

Morrow GS, Litton CD [1992]. In-mine evaluation of smoke detectors. Pittsburgh, PA: U.S. Department of the Interior, Bureau of Mines, IC 9311.

Moser W [1993]. Mine emergency preparedness. In: Proceedings of the SME Annual Meeting, preprint 93-53. Littleton, CO: Society for Mining, Metallurgy, and Exploration, Inc.

Strahin RA, Wolf DN, Pogue CW [1990]. Report of investigation, mine fire, Marianna No. 58 (ID No. 36-00957), March 7, 1988. U.S. Department of Labor, Mine Safety and Health Administration, March.

Vaught C, Fotta B, Wiehagen WJ, Conti RS, Fowkes RS [1996]. A profile of workers' experience and preparedness in responding to underground mine fires. Pittsburgh, PA: U.S. Department of the Interior, Bureau of Mines, RI 9584.

## APPENDIX A.—NIOSH UNDERGROUND COAL MINE FIRE PREPAREDNESS AND RESPONSE CHECKLIST

(*Please feel free to photocopy.*)

## WATER SUPPLY

All text within a bordered box throughout appendix A represents language from 30 CFR.

75.1100-1(a) - Waterlines shall be capable of delivering 50 gallons of water a minute at a nozzle pressure of 50 pounds per square inch.

75.1100-1(b) - A portable water car shall be of at least 1,000 gallons capacity and shall have at least 300 feet of fire hose with nozzles. A portable water car shall be capable of providing a flow through the hose of 50 gallons of water per minute at a nozzle pressure of 50 pounds per square inch.

75.1100-2(a) - Each working section shall be provided with two portable fire extinguishers and 240 pounds of rock dust in bags or other suitable containers; waterlines shall extend to each section loading point and be equipped with enough fire hose to reach each working face.

C Is there a map of the water system? Yes	_ No
Where is the map located?	
	·
Who is the contact person?	
When was the map last updated?	
• Availability of mine water: Unlimited supply	
Reservoir	Approximate gallons:
Other source	Approximate gallons:
• Do you have water cars? Yes No	
If yes, what is the total number of water cars?	·
Approximate gallons:	

•	Quality	of	underground	mine	water:
---	---------	----	-------------	------	--------

Caustic \_\_\_\_\_ Acidic \_\_\_\_\_ pH level \_\_\_\_.

(A pH level >7 indicates caustic; <7 indicates acidic)

Hardness\_\_\_\_\_ mg/L (200 is normal for drinking water)

Total dissolved solids (TDS) \_\_\_\_ mg/L.

• If your water lines are in your beltline, please complete the following. If not, please explain:

Is waterflow and airflow in the same direction on main water lines?

Yes \_\_\_\_ No \_\_\_\_.

If no, what precautions are used if smoke is outby a fire and you need water for firefighting?

Is waterflow and airflow in the same direction on *branch water lines*?

Yes <u>No</u> Varies .

If no, what precautions are used if smoke is outby a fire and you need water for firefighting?

• Are safety valves (shutoff ball valves) supplied, for example, if line is broken? Yes \_\_\_\_\_ No \_\_\_\_\_

Spacing of valves \_\_\_\_\_

•	Location of main water pump stations:	Underground	Surface	None

If you have a main water pump station, indicate type:

Electrical \_\_\_\_\_ Diesel \_\_\_\_\_ Other \_\_\_\_\_.

• Type of backup systems: Pump \_\_\_\_\_ Water Supply \_\_\_\_ None \_\_\_\_.

If you have a pump-operated backup system, indicate type:

Electrical \_\_\_\_ Diesel \_\_\_\_ Other \_\_\_\_.

75.1100-2(b) - *Belt conveyors.* Waterlines shall be installed parallel to the entire length of belt conveyors and shall be equipped with firehose outlets with valves at 300-foot intervals along each belt conveyor and at the tailpieces. At least 500 feet of firehose with fittings suitable for connection with each belt conveyor waterline system shall be stored at strategic locations along the belt conveyor. Waterlines may be installed in entries adjacent to the conveyor entry belt as long as the outlets project into the belt conveyor entry.

75.1100-2(c) - *Haulage trucks*. Waterlines shall be equipped with outlet valves at intervals of not more than 500 feet, and 500 feet of firehose with fittings suitable for connection with such waterlines shall be provided at strategic locations. Two portable water cars, readily available, may be used in lieu of waterlines prescribed under this paragraph.

• What is the spacing of your water hydrants/fire taps/hose drops/etc.? \_\_\_\_\_ ft.

• Water hydrant size(s): \_\_\_\_\_ in.

Type of fitting: NST \_\_\_\_\_ Pipe \_\_\_\_ Other \_\_\_\_.

Approximate height of water hydrants from floor: \_\_\_\_\_ ft.

• Position of water hydrants outlet: Up \_\_\_\_ Down \_\_\_\_ Sideways \_\_\_\_ Varies \_\_\_\_.

*NOTE:* Water hydrant outlets, etc., positioned downward collect sediment and must be flushed before connecting water hoses.

Is the water pressure adjustable? Yes \_\_\_\_\_ No \_\_\_\_\_.

If yes, do you have a written procedure to adjust the water hydrant pressure?

Yes \_\_\_\_ No \_\_\_\_.

Type of valve(s) on water hydrant: ball valve 10-turn valve											
Other Please explain:											
Can you use more than one hose at each manifold/hydrant?											
Yes No											
Please explain:											
• Are the locations of your water hydrants marked (examples: sign, painted rod)?											
Yes No											
Type of marking:											
Location of markings: Near roof Center of entry Other											
Do these markings vary throughout the mine? Yes No											
C Are the water hydrants marked in adjacent entries? Yes No											
If yes, how are they marked?											
Are the water hydrants accessible from adjacent entries? Yes No											
• Approximately how much access room is there between rib and belt? (This is important when connecting water											
lines and evacuating in smoky conditions):											
(Note: 24-in minimum requirement.)											
<i>Main</i> - Clearance between tight side of belt and rib: ft.											
Clearance between wide side of belt and rib: ft.											
Section - Clearance between tight side of belt and rib: ft.											
Clearance between wide side of belt and rib: ft.											

75.1103 each fir maintai	-11 - Each fire hydrant shall be tested by opening to insure that it is in operating condition, and e hose shall be tested, at intervals not exceeding 1 year. A record of these tests shall be ned at an appropriate location.
• Inspec	tions are conducted every months.
	Are functional tests performed? Yes No
-	Are written records maintained? Yes No
• Is wat	er available in remote locations (areas not used)? Yes No
I	f yes, what is the water pressure and flow in these areas? psig: gpm:
I	f no, what method would be used to supply water to these locations? Pipe Hose Size(s) Other
V	What would be the expected water pressure in these locations?psig.
, Can yc during	an emergency (for example, water in remote areas or failure of existing water lines)? Yes
No It	f yes, how difficult or time-consuming is the conversion?
_ D	Do you have a conversion kit for this purpose? Yes No

*NOTE:* When conducting the following tests, flush the water taps before connecting the water hose.

• Please complete the following table on main water lines.

	SIZE, in	SIZE, in SCHEDULE	MATERIAL TYPE	SAFE OPERATING PRESSURE, psig	MEASURED WATERFLOW AT FIRE HYDRANTS									
MAIN					TEST LOCATION 1		TEST LOCATION 2			TEST LOCATION 3		ion 3		
WATER LINE NAME					I	osig		psig				psig		
					Static	Dynamic	gpm	Static	Dynamic	gpm	Static	Dynamic	gpm	

#### MAIN WATER LINES

*NOTE:* When conducting the following tests, flush the water taps before connecting the water hose.

• Please complete the following table on branch water lines.

	SIZE,	IZE.	MATERIAL	SAFE OPERATING	MEASURED WATERFLOW AT FIRE HYDRANTS									
BRANCH					TEST LOCATION 1			TEST LOCATION 2			TEST LOCATION 3		ION 3	
WATER LINE NAME	in	SCHEDULE	TYPE	PRESSURE,	psig		~~~~~	psig		~~~~~	psig		~~~~~	
				Sta	Static	Dynamic	gpm	Static	Dynamic	gpm	Static	Dynamic	gpm	

#### BRANCH WATER LINES

75.1100-1(f)(1) - The fire hose shall be lined with a material having flame resistant qualities meeting requirements for hose in Bureau of Mines' Schedule 2G.

Inspection intervals every \_\_\_\_\_ months.

What are the procedures?

What is your procedure for damaged or deteriorated water hose (replaced/repaired)?

Is testing according to NFPA 1962 Standard for the care, use, testing, and service of fire hose, incluc

\_ ·

couplings and nozzles? Yes \_\_\_\_ No \_\_\_\_.

If no, what do you do?

• Please complete the following table of fire nozzles:

Total Number								
Expensive <sup>1</sup>			Inexpe	nsive <sup>2</sup>	Size,	Thread,	Pressure	
Surface	Under-	Sur	face	Under	ground	in	type	rating, psig
	ground	Brass	Plastic	Brass	Plastic			

FIRE NOZZLES
--------------

<sup>1</sup>Nozzle over \$200 and fully adjustable. <sup>2</sup>Nozzle under \$50. • Please complete the following table on fire water hoses:

Size, Thread,	Pressure	Pressure Total length, ft			Location		
in	type	Material	Pressure rating, psig	Surface	Underground	Surface	Underground

FIRE WATER HOSES

• Do you have couplers/reducers to attach nozzles to larger diameter water hose?

Yes <u>No</u>.

• Please complete the following tables on water throw distance (recommend 100 ft minimum)

Location	Nozzle	Hose size,	Entry	Static pressure,	Throw	Dynamic conditions	
	type	in	height, ft	psig	distance, ft	Dyr cond psig	gpm

THROW DISTANCE - SOLID STREAM (MAIN BELTLINE)

#### THROW DISTANCE - SOLID STREAM (BRANCH BELTLINE)

Location	Nozzle	Hose size.	Entry	Static pressure.	Throw	Dynamic conditions	
	type	in	height, ft	psig	distance, ft	Dyn cond psig	gpm

## FOAM FIREFIGHTING EQUIPMENT

• Do you have foam generators at your mine? Yes \_\_\_\_\_ No \_\_\_\_.

If no, skip this section.

• Please complete the following table on foam generators:

Location	Handheld			Water-Powered			Diesel-Powered			Other		
	Brand	Expansion Ratio	Total Number	Brand	Expansion Ratio	Total Number	Brand	Expansion Ratio	Total Number	Brand	Expansion Ratio	Total Number

TYPE OF FIREFIGHTING FOAM GENERATORS ON SITE

• Can foam nozzles be used with your water lines or fire hose? Yes No
• Do you have the capability of using foam eductors? Yes No
• If foam concentrate is stored on the surface, is it protected from extreme weather
temperatures? Yes <u>No</u> .
• Are the foam concentrate containers stacked according to the manufacturer's
recommendations? Yes <u>No</u> .
• Is the foam concentrate in closed containers? Yes <u>No</u> .
• Do you inspect/test the foam concentrate? Yes <u>No</u> .
• Is your foam concentrate compatible with your mine water supply? Yes <u>No</u> .
If no, why?
Is your foam equipment compatible with foam concentrate? Yes No      If no, why?
Do you have trained people to use foam equipment? Yes No  When was the last time this equipment was tested?
If you have more than one brand of foam concentrate, have you tested the quality of foam production if brands are
mixed?
Yes No Only one brand used
If yes, what were the results?

Have y	you tested the foam generators in your mine? Yes <u>No</u> .
If yes,	what problems did you experience, if any?
Forexa	ample, if you were using a diesel-powered, high-expansion foam generator in an upward sloping entry, what
would	you do to prevent the foam plug from rolling back over the foam generator?
P	lease explain:
Do you	u have procedures for inspecting foam generators? Yes No .
If	ves what are these procedures?
	·

• Please complete the following table on foam concentrate:

Foam		Sto	Percent	Total amount,			
type	Surface	Unit	Underground	Unit	concentrate	gal	

#### FOAM CONCENTRATE

If you run out of foam during an emergency, do you have a supplier? Yes \_\_\_\_\_ No \_\_\_\_\_.

How long would it take to receive the foam?

## FIRE EXTINGUISHERS

75.1100-3 - *Condition and examination of firefighting equipment*. All firefighting equipment shall be maintained in a usable and operative condition. Chemical extinguishers shall be examined every 6 months and the date of the examination shall be written on a permanent tag attached to the extinguisher.

• How often do you inspect fire extinguishers? Every \_\_\_\_\_ months.

What are the procedures?

• Are you aware that if a fire extinguisher is not handled for extended periods of time, the dry chemical can settle and compact?

Yes \_\_\_\_\_ No \_\_\_\_.

• Are you aware that caking occurs when moisture contacts the dry chemical due to faulty gaskets and rusty extinguishers?

Yes <u>No</u>.

• Are hydrostatic test dates of fire extinguishers and pressure vessels checked?

Yes \_\_\_\_\_ No \_\_\_\_.

• Do you realize the hazards of rusty fire extinguishers and pressure vessels?

Yes <u>No</u>.

What are they?

• Do you have a plan to handle damaged, partially used, and rusty fire extinguishers?

Yes <u>No</u>.

What is done with rusty fire extinguishers (repair/replace)?

How is this handled?

• .	Are your employees	trained to ide	ntify defective	e fire extinguishers?	Yes	No	
-----	--------------------	----------------	-----------------	-----------------------	-----	----	--

• Are fire extinguishers exposed to mud or wash plant overflows? Yes <u>No</u>.

If yes, how are they protected (example: shields, storage boxes)?

75.1100-2(d) - *Transportation.* Each track or off-track locomotive, self-propelled mantrip car, or personnel carrier shall be equipped with one portable fire extinguisher.

75.1100-2(e)(1) - *Electrical installations*. Two portable fire extinguishers or one extinguisher having at least twice the minimum capacity specified for a portable fire extinguisher in 75.1100-1(e) shall be provided at each permanent electrical installation [greater than 6 months].

75.1100-2(e)(2) - Electrical installations. One portable fire extinguisher and 240 pounds of rock dust shall be provided at each temporary electrical installation [less than 6 months].

75.1100-2(g) - Welding, cutting, soldering. One portable fire extinguisher or 240 pounds of rock dust shall be provided at locations where welding, cutting, or soldering with arc or flame is being done.

• Are you prepared for on-site recharge of fire extinguishers? Yes \_\_\_\_\_ No\_\_\_\_\_.

If yes, what is the number of on-site trained people to recharge fire extinguishers?\_\_\_\_\_.

Quantity of charged cartridges: \_\_\_\_\_

Dry-chemical powder \_\_\_\_\_ lb.

If no, what is the timeframe for acquiring new fire extinguishers or having an

outside contractor recharge them?
\_\_\_\_\_

• Please complete the following table on fire extinguishers:

	Portable/stored		Wheeled		Skid	
Location	lb	Total Number	lb	Total Number	lbs	Total Number

#### FIRE EXTINGUISHERS - UNDERGROUND

• Please complete the following table on fire extinguishers:

	Portable/stored		Wheeled		Skid	
Location	lb	Total Number	lb	Total Number	lb	Total Number

#### FIRE EXTINGUISHERS - SURFACE

#### FIRE STATIONS

(Fire stations include cars, houses, trailers, boxes, foam generator trailers, sleds, etc.)

75.1101-23(a)(1)(ii) - Rapid assembly and transportation of necessary men, fire suppression equipment, and rescue apparatus to the scene of the fire. 75.1100-2(i) - Emergency materials. 75.1713-7 - First-aid equipment; location; minimum requirements. • Total number of fire stations: \_\_\_\_\_. Locations: Underground \_\_\_\_\_ Surface \_\_\_\_\_. Are the stations easily transported to the fire area? Yes \_\_\_\_\_ No \_\_\_\_. If no, why? How are they transported? Do they require special handling or components, like hitches? Yes \_\_\_\_\_ No \_\_\_\_. What are the special handling requirements?

- Is the station equipped with a pager phone and extra wire? Yes \_\_\_\_\_ No \_\_\_\_.
- Do you have an up-to-date plastic laminated mine map with grease pencils located on the station?
   Yes \_\_\_\_\_ No \_\_\_\_.
- Some mines utilize fire hose in various sizes (1.5- to 2.5-in-diam) or a lightweight high-volume (5- to 6-in-diam) nonpolarized hose fitting. What size hose do you use on your station?

• A portable hose clamp is used to temporarily stop the waterflow in hoses to reduce delays caused by turning the main water supply on or off if problems are encountered. Do you have a hose clamp on your station?

Yes \_\_\_\_ No \_\_\_\_.

• Spanner wrenches are used to detach fire hoses and fittings (the wrenches are small and easily lost, so several wrenches should be available). Do you provide spanner wrenches on your station?

Yes \_\_\_\_\_ No \_\_\_\_.

- Do you provide special hose nozzles that are suitable for firefighters and are appropriate to use with the mine water pressure and equipment? Yes \_\_\_\_\_ No \_\_\_\_.
- Are booster pumps provided on the station to raise water pressure? Yes \_\_\_\_\_ No \_\_\_\_\_.

If yes, enter the total number in the following categories:

Diesel \_\_\_\_\_ Electric \_\_\_\_\_ Other \_\_\_\_.

• Are regulators provided on the station to lower the water pressure? Yes \_\_\_\_\_ No \_\_\_\_\_.

•	Is firefighting	foam equipment	t and a supply of foam	concentrate available on	the station?
---	-----------------	----------------	------------------------	--------------------------	--------------

Туре	of foam equipment stored on the station?
	How much foam concentrate is stored on the station?
	Where do you go if you run out of foam concentrate during an emergency?
	How long would it take to retrieve it?
Are j	portable fire extinguishers available? Yes No
Is a s	upply of dry-chemical agent with replacement gas cartridges available?
	Yes No
	Please explain:
Are y Pleas	wheeled or skid-mounted fire extinguishers provided on the station? Yes No
Are	various tools and supplies provided on these trailers/fire cars? Yes No
	What kinds of tools and supplies?

• Roof jacks may be necessary for temporary roof support. Are they provided on the
stations? Yes No
• Hydraulic pump jacks may be necessary to lift heavy objects. Are they provided on
the station? Yes No
• Are first-aid kits to treat minor burns and injuries provided? Yes No
Please explain:
Personal Protective Equipment (PPE)
• Is personal protective clothing available for firefighters on the station? Yes No
• Number of SCBAs ( <i>not</i> SCSRs) provided on the station:
Miscellaneous
• Total amount of rock dust provided on the station:
Is the rock dust protected from moisture? Yes No Sometimes
Please explain:
<ul> <li>Does everyone know the location of these stations and procedures to be followed when moving to fire location?</li> <li>Yes No</li> </ul>
Please explain:
Who is responsible for inspecting, maintaining, and using the stations?
How often is this inspection conducted?

What constitutes an inspection?				
·				
Are records/logs kept? Yes No				
Location of records:				

### **DETECTION SYSTEMS**

75.1103-1 - *Automatic fire sensors*. A fire sensor system shall be installed on each underground belt conveyor. Sensors so installed shall be of a type which will (a) give warning automatically when a fire occurs on or near such belt; (b) provide both audible and visual signals that permit rapid location of the fire.

FIRE SENSORS						
Sensor type	Location	Total number	Spacing, ft	Vertical position from floor, ft		

• What is the CO background level if using diesel equipment? \_\_\_\_\_ ppm.

Manufacturer of CO system?

Warning level \_\_\_\_\_ ppm Alarm level \_\_\_\_\_ ppm.

Manufacturer of thermal system?
Alarm level:EF
Manufacturer of smoke sensor:
Manufacturer of diesel-discriminating sensor:
• Is there battery backup in case of electrical failure? Yes No
If yes, how much time?
• Are there any unusual problems with the fire sensors? Yes No
Please explain:
·
• Do you have a problem with <i>false</i> or <i>nuisance</i> fire alarms? Yes No
What is the frequency (number of false alarms per month)?
·
Where is the location of false alarms?
What is the cause of false alarms?
·
• Do you have a hot work permit (welding/cutting)? Yes No
Please explain:

Location of monitoring room? Aboveground	
Other:	
<ul> <li>Is the person in monitoring room trained in proper response to sensor alerts and alarms?</li> <li>Yes No What is the training?</li> </ul>	·
<ul> <li>Is there a procedure for checking wire continuity, sensor function, cable clearance around moving machinery,</li> <li>Yes No</li> </ul>	tc.?
• Are these wires/cables redirected around areas that have a high potential for fire (for examplet, dr	ives,
brake stations, etc.)? Yes No Please explain:	
• Is the sensory element of the fire sensor oriented into the airflow (this is critical with only certain brands of sensor Yes No Varies	 ors)?
• Are there any moisture, electrical, or other problems with the sensors? Yes No Please explain:	

.

75.1103-8 - Automatic fire sensor and warning device systems; inspection and test requirements.

• What are the	intervals of functional tests (a complete test of the system from underground sensor to surface
computer)?	<u>.</u>
What are the	calibration intervals?
What kind o	f general training is provided for individuals who handle, install, and calibrate fire sensors
What kind of t	raining is provided, in general, to better acquaint all miners in the day-to-day operation of fire sensors
(for example	, better communications when using equipment near sensors, welding/cutting operations, diesel
equipment, e	etc.)?
Please expla	in:

\_ •

Where are the	phone lines located?
Are phones an	d other communication cables protected from areas prone to fires?
Yes	No
Please explain	
ou have a spect	alized fire warning alarm system to alert all miners of an emergency?
Please explain	
	SUPPRESSION SYSTEMS
	SUPPRESSION SYSTEMS
)1-1 - Deluge-type )1-5 - Installation )1-6 - Water sprir )1-13 - Dry powd	SUPPRESSION SYSTEMS water spray systems. of foam generator systems. kler systems; general. r chemical systems; general.
01-1 - Deluge-type 01-5 - Installation 01-6 - Water sprir 01-13 - Dry powd	SUPPRESSION SYSTEMS e water spray systems. of foam generator systems. kler systems; general. er chemical systems; general.
01-1 - Deluge-type 01-5 - Installation 01-6 - Water sprir 01-13 - Dry powd functional tests	SUPPRESSION SYSTEMS e water spray systems. of foam generator systems. kler systems; general. er chemical systems; general. of suppression systems performed? Yes No
01-1 - Deluge-type 01-5 - Installation 01-6 - Water sprir 01-13 - Dry powd functional tests 70u follow a che	SUPPRESSION SYSTEMS         e water spray systems.         of foam generator systems.         kler systems; general.         er chemical systems; general.         of suppression systems performed? Yes No         scklist? Yes No
01-1 - Deluge-type 01-5 - Installation 01-6 - Water sprir 01-13 - Dry powd functional tests 70u follow a che What is the pro	SUPPRESSION SYSTEMS water spray systems. of foam generator systems. kler systems; general. ar chemical systems; general. of suppression systems performed? Yes No cklist? Yes No

How often are suppression systems checked?

• Please complete the following table on suppression systems.

Location	Water deluge	High-expansion foam	Dry-chemical	Water sprinkler

#### SUPPRESSION SYSTEMS UNDERGROUND

• When the water sprinkler system is activated, will the water spray cover the entire cross-section of the entry? Yes

• Are water sprinkler heads changed? Yes \_\_\_\_\_ No \_\_\_\_.

If yes, what is the time period? \_\_\_\_\_.

• Are shutoff valves normally left open? Yes \_\_\_\_\_ No \_\_\_\_.

How do you ensure that the shutoff valves are open, and if they were closed during a fire, could they be

.

opened?

Please comment:

What are the procedures?	
Are records/logs kept? Yes No	·.
• Do you utilize water barriers (wall of water)? Yes No	

If yes, please complete the following table on water barriers (wall of water).

WATER BARRIERS (WALL OF WATER)

Location	Spacing interval	No. of spray nozzles per cross-section	Activation temperature, °F	Waterflow, gpm

 $\bullet \ If water barriers (wall of water) are located in the belt entry, are they positioned in the middle of the block? \ Yes$ 

\_\_\_\_ No \_\_\_\_ N/A \_\_\_\_.

 $\texttt{C} \ \ \texttt{D} o \ you \ utilize \ water \ \texttt{lances} \ (pipe \ with \ water \ \texttt{sprays} \ \texttt{that} \ \texttt{can} \ \texttt{be} \ \texttt{inserted} \ \texttt{through} \ \texttt{stoppings} \ \texttt{or} \ \texttt{doors} \ \texttt{downwind} \ \texttt{of}$ 

a fire)? Yes \_\_\_\_ No \_\_\_\_.

Please explain:

### VENTILATION

• Is your mine fan a blowing or exhausting fan?
• Can you reverse the direction of your fan? Yes No
If no, could it be modified during an emergency? Please explain:
C Do you have a ventilation plan for various fire scenarios that could occur in your mine?
Yes         No         Please explain:
C How many people are familiar with the ventilation plan?
Please explain:
Do miners on each section know where the air comes from and where the air goes (for example, location of
fans, ventilation materials, etc.)? Yes No
C Do you conduct training exercises to show how to ventilate (for example, battery fire, belt fire)?
Yes No
Please explain:
Do all miners participate in these drills? Yes No
C Do you isolate your haulage road from the beltline? Yes No
C Would you split your intake air before inby miners are out of the mine during a fire?
Yes No

	Please explain:
C Is so	meone knowledgeable about the mine's ventilation system if changes are to be made (for example, where to
dum	p the air)? Yes No
	Please explain:
C Doa	Il workers understand their role in implementing the fire ventilation plan if there is a fire in their section? Yes
	Please explain:
• Is ea	ch section provided with a one-page write-up (bullet form) on how to respond to inby and outby fires (for nple, procedures to be followed for an inby belt fire)? Yes No .
	Please explain:

### COMBUSTIBLE MATERIALS UNDERGROUND

Coalbed mined		
Coal rank <sup>1</sup>		
Moisture <sup>2</sup> , %		
Volatile matter <sup>2</sup> , %		
Fixed carbon <sup>2</sup> , %		
Ash <sup>2</sup> , %		
	Organic, %	
Sulfur	Pyritic, %	
	Sulfate	
Heating value, Btu per pound		

COAL CHARACTERISTICS (IN-PLACE)

<sup>1</sup>For example, high-volatile A bituminous.

<sup>2</sup>From proximate coal analyses, as-received values.

### Title 30, Chapter I, Subchapter B—Testing, Evaluation, and Approval of Mining Products

If you utilize conveyor belting, please complete the following table on conveyor belt.

CONVEYOR BELT

		Belt characteristics			Lassien
Brand/type	Width, in	Ply	MSHA No.	Length, ft	Location

C Do you use plastic resin roof bolts? Yes \_\_\_\_\_ No \_\_\_\_.

• Please complete the following table on combustible materials stored or used underground:

Material	Quantity	Unit	To	oxic level due to	burning	Special precat (above and beyond MSI	itions HA regulations)
			Low	Medium	High	Fires	Explosions
Brattice							
Conveyor belting							
Diesel fuel (storage and vehicles)							
Electrical cables							
Fluids (emulsion)							
Fluids (hydraulic)							
Grouting							
Oils							
Plastic piping							
Roof bolt resins							
Lumber (untreated)							
Lumber (treated)							
Tires (on equipment)							
Ventilation tubing							
Oxygen							
Acetylene							
Propane							

#### COMBUSTIBLE MATERIALS STORED OR USED UNDERGROUND

## HOUSEKEEPING

•	Do you have any surface hazards that can affect the underground mine (for example, propane storage tanks)? Yes
	No
	Please list:
С	Do you store compressed gas cylinders underground? Yes No
	If yes, how and where do you store compressed gas cylinders?
C	Do you have a battery disposal program? If yes, please explain:
С	Are old batteries removed from the underground mine? Yes No
•	How do you handle hazardous waste, such as antifreeze, emulsion oil, etc.?
	,
•	How do you handle underground fuel spills (for example, diesel fuel)?
	·

• What is done with	underground trash?
Are your crosscut	s, with mandoors, free of obstructions, such as mine materials, equipment, etc.?
Yes N	0
Please expla	in:
Are your crosscut	s or areas used to store emergency equipment free of obstructions?
Yes N	0
Please expla	in:
Do miners have a Yes N Please expla	n opportunity to assess their work area and personal protective equipment? No in:
How do you contr	ol the buildup of excess coal dust on beltlines?
What procedures	are used to inspect and dispose of residue from belt and V-plow scrappers?

How many belt scrapers do you have underground?
How many V-plow scrapers do you have underground?
What procedures are used to reduce belt thread buildup?
• Are your belt drive areas covered with a noncombustible material? Yes No
• Are your power center areas covered with a noncombustible material? Yes No
• Are your charging station areas covered with a noncombustible material? Yes No
What is done to control the caking of rock dust and coal dust on sprinkler heads?

# **EVACUATION PLANS**

75.380 - Escapeways; bituminous and lignite mines.
75.384 - Longwall and shortwall travelways.
75.1101-23(a) - Each operator of an underground coal mine shall adopt a program for the instruction of all miners in the location and use of fire fighting equipment, location of escapeways, exits, and routes of travel to the surface, and proper evacuation procedures to be followed in the event of an emergency.
• Do you incorporate your evacuation plan in your drills? Yes No
Piease explain:
How often do miners walk the escapeway?

	Do miners walk the entire escapeway or just part of the way?
How	much time is required to walk the escapeway from the section to the portal?
How	do you maintain your escapeways?
	Please explain:
How	are your escape routes identified?
	Are they identifiable in smoke? Yes No
	Please explain:
5.17 utho dequ	SELF-CONTAINED SELF-RESCUERS (SCSRS) I4(a) - Each operator shall make available to each miner who goes underground, and to visitors rized to enter the mine by the operator, an approved self-rescue device or devices which is late to protect such person for 1 hour or longer.
Wha	t brand and model of SCSR is used at the mine? (If more than one type, please list all.)
How	often is refresher training conducted?
How	many SCSRs are stored underground?
	Total number: MSA CSE Ocenco

	Where are your unde	rground SCSR cach	es located?		
• How	many SCSRs are sto	red on the surface?			
	Total number:	MSA	CSE	Ocenco	
		Draeger	Other		
C How	are SCSRs with expire	red service life remo	ved from serv	vice?	
Plea	se explain:				
	What is done with th	ese units?			
	Are records/logs kep	ot of these units? Y	es No	·	
	Please explain:				
	Are serial numbers r	ecorded? Yes	No		
C How	v are these units tracke	ed after they are take	en undergrou	nd?	
	Please explain:				
C Are	units visually inspecte	ed for damage? Yes	s No _		
	How often?				
	Who inspects them?	Please explain:			

C What is done with damaged units?	
Are records kept of inspections and removal of damaged units? Yes No	
C Does your mine participate in NIOSH's Long-Term Field Evaluation Program?	
Yes No	
Date of last replacement:	
Total number of units replaced:	
Has your mine experienced any problems with SCSRs? Yes No	
Please explain:	
FIRST RESPONDERS TO FIRE <sup>1</sup>	
75.1101-23 - Program of instruction; location and use of fire fighting equipment; location of escapeway	/S,
exits and routes of travel; evacuation procedures; fire drills.	
• How often are fire drills conducted?	
• What kind of training is conducted for miners responding to a fire?	
First responders are the first persons to initiate firefighting.	

• Who cond	lucts training?
If ou	tside vendor/consultant, please list:
• What kind	I of firefighting equipment is used in training?
Extin	nguishers Fire hose Fire suppression systems
Foan	n generators Other (please explain)
• During tra	uning, are real fires extinguished? Yes No
If yes	s, describe fire scenario:
• Howoften	n is fire training conducted?
• Is smoke t	training conducted? Yes No
If yes	s, describe scenario:
Туре	of apparatus used:
• What type	of training is conducted for SCSRs or filter self-rescuers?

• Do miners have specific duties if there is a fire on their section? Yes No
If yes, what are their duties for the section?
what are their duties if they are outby?
• What percentage of miners are trained in first aid?%.
• Do you have a standard operating procedure (SOP) for first person to respond to a fire?
Yes No
Please explain:
How many miners are trained overall?
• How many per section?
• Do you have an agreement for assistance from the local fire department, for example, fighting surface fires or the
use of fire hose and water? Yes No
What precautions are taken (on-site training, liability)?
• Do you have a mutual agreement with other mines to fight fires? Yes No
If yes, do you train together, etc.? Yes No
Please explain:

## FIRE BRIGADES

C Do you have a fire brigade? Yes No (If no, skip this section.)
• How many teams do you have?
How many members per team?
How are members selected?
What are the criteria for being on the fire brigade?
• How often do fire brigade members train?
Describe training:
• Do fire brigade members train with the mine rescue team members? Yes No
• Do you provide your fire brigade with specialized equipment? Yes No
Please explain:
• How much time is required for the fire brigade team to muster and respond to an underground fire?

Describe training:
• If you have more than one team, is cross-training provided? Yes No N/A
• Has your team ever trained with your State mine rescue teams? Yes No
• Do mine rescue team members train with the fire brigade members? Yes No
• Do you provide your mine rescue team with specialized equipment? Yes No
Please explain:
• How much time is required for the mine rescue team to muster and respond to an underground fire
Do you have an SOP for mine rescue? Yes No      Please explain:
• Has your team ever participated in an actual mine emergency? Yes No
Please explain:
SPECIALIZED EQUIPMENT
What type of turnout gear do you have?

Total number: Where are they stored?
Do personnel have easy access to it? Yes No
What types of SCBAs do you have?
Please enter the total number of units:
30-min 60-min 4-hr Other
Location:
Explain your SCBA preventive maintenance program.
Are records/logs kept? Yes No
C Do you have extra tanks of air? Yes No
• Do you have the capabilities of charging your own tanks? Yes No .
If ves is your system a cascading system? Ves No
If yes, is your system a cascading system? Tes NO
• Do you provide motion sensors for team members? Yes No
• Do you have infrared devices or thermal imaging cameras for locating hot spots, fires, or missing
miners? Yes No
Please explain:
• W
-----
• 0
0

### APPENDIX B.—EXAMPLES OF INSPECTION, MAINTENANCE, AND GENERAL HOUSEKEEPING CHECKLISTS AND PROCEDURES

#### ANNUAL HYDRANT CHECKS

#### 30 CFR 75.1103-11

- 1. Checked with Conflow fire hydrant setting bend:
  - a. Unlock the presetting dome by loosening the three set screws with an Allen wrench. Rotate presetting dome by hand in a clockwise direction all the way out.
- 2. Connect the presetting bend onto the hydrant outlet using a 1.5-in pipe thread to NST thread adapter.
- 3. Use the 0.5-in presetting bend nozzle.
- 4. Use caution when applying pressure flow through the 0.5-in nozzle. Hold the nozzle tightly, directing the waterflow in a harmless direction so as not to hurt yourself or someone in the area or to cause damage to equipment.
- 5. Open the hydrant with the handwheel until the flow gauge is registering 120 psig.
- 6. Rotate the presetting dome by hand in an anticlockwise direction until it can move no further.
- 7. Lock the presetting dome in this position by tightening the three set screws.
- 8. Double-check the psi setting by opening the handwheel as far as possible; the flow gauge should read 120 psi.
- 9. Remove the presetting bend and adapter from the hydrant and replace hydrant cap.
- 10. Punch tag in proper place.

### **ANNUAL FIRE HOSE CHECKS**

### 30 CFR 75.1103-11

- 1. Designated fire hose storage area consists of the following:
  - a. Ten 50-ft hoses are donut-rolled and placed in a blue 55-gal plastic barrel with two pogo poles taped with red and white reflective tape. There is a white sign with red reflective letters stating "fire hose."
  - b. Two brass fire hose nozzles screwed on a gated Y are placed on top of the hoses, which are stored in the barrel.
- 2. Hose spacing
  - a. Main north travelway every 1,000 ft.
  - b. Panel section every 2,000 ft or less, in an X-cut on the belt side of No. 2 entry. If muddy or wet conditions exist on the belt side, the hose is placed on the uphill side. Both sides are on intake ai
  - c. If a belt drive is between this 2,000-ft spacing, then another barrel of hose is placed there.
- 3. Hose testing
  - a. Every hose is pulled out of the rack or reel and checked for leaks. If a hose is found to have any kind of leak, even a pinhole, the hose is replaced (cut both ends off of hose and discard).
  - b. The 50-ft hoses have a pressure check of 400 psi. To obtain that kind of pressure, a direct hookup to the water line is used. A gated valve and pipe with a pressure gauge are connected to the gated Y where the hoses are hooked up and laid out for testing. The hoses are laid out flat and the nozzles are opened slightly to prevent a water hammer. The water is turned on and the nozzles are closed after water flows through the nozzles. The water has pressure readings of 400 psi, and the water is left on for 2 min to check for leaks. The rating on the 100-ft hose found in some safety trailers is 250 psi; that is the pressure at which they are checked.

# ANNUAL FIRE HOSE TESTS

SITE LOCATION									
DATE TESTS WERE COMPLETED:									
HOSE LOCATION	HOSE LENGTHS	LENGTHS TESTED	PRESSURE USED	COMMENTS, DEFECTS, ETC.					

## MONTHLY CHECKS ON FOAM GENERATOR

In a toolbox on the foam generator, there is a notebook that contains a complete listing of various items that should be on the generator. There are also a series of tests and checks to be made. After completing the inventory list and making the necessary series of checks and tests, the person that does these checks signs his or her name and states if anything is missing or wrong with the generator. If anything is missing or wrong with the generator, it must be reported to management and corrected immediately.

Items on, or tests to be made on, foam generator.

- 1. Check oil
- 2. Check fuel
- 3. Start generator
- 4. Check cage (for dents, punctures, etc.)
- 5. Check tires
- 6. Wheel chocks (3)
- 7. Six 2.5-in red rubber hoses
- 8. Seven 1.5-in cloth hoses
- 9. Fifteen 3-in cloth (400-psi) hoses in racks
- 10. One crank handle for starting the engine
- 11. One pressure reducer valve
- 12. One gang valve
- 13. One hose clamp
- 14. Two bull hoses
- 15. One fire extinguisher
- 16. Two 30-gal barrels of foam concentrate
- 17. Ax
- 18. Eight 4-in Vic couplers

- 19. Eight pogo sticks
- 20. Two sand bags
- 21. One diesel can, 2.5 gal full
- 22. One can spads
- 23. One can buttons
- 24. One 4-ft spad gun
- 25. One 6-ft ladder
- 26. One bow saw
- 27. Two shovels (one spade, one blunt end)
- 28. One pick
- 30. Four rolls brattice cloth
- 31. Two telephones (test system)
- 32. One 8-lb sledge hammer
- 33. One hitch
- 34. Approximately 300 ft telephone cable
- 35. Extracrank handle mounted on side of hose rack

Items in tool box:

- 1. Three 24-in pipe wrenches
- 2. One 18-in pipe wrench
- 3. Two 0.5-in drive ratchets
- 4. Two 1-1/16-in (0.5-in drive) sockets
- 5. One wire brush
- 6. Two Akron nozzles
- 7. Various nozzles, fittings, and couplers
- 8. Foam generator instruction manual
- 9. Two 12-in crescent wrenches
- 10. One 8-in crescent wrench
- 11. One 6-in crescent wrench
- 12. One spanner wrench
- 13. One set Allen wrenches

- 14. One 460 channel lock pliers
- 15. Two 2.5-lb hammers
- 16. One claw hammer
- 17. Three 6-in Vic couplers
- 18. One 2-in Vic couplers
- 19. One 1.25-in (0.5-in drive) socket
- 20. One 6- to 4-in Vic reducer
- 21. One extra bow saw blade
- 22. One funnel and 1-in hose
- 23. Functional test overhead door (manual and electrical)
- 24. Annually drain and refill fuel tank and diesel can

LOCATION: _			
DATE:			
EXAMINER:			

#### FOAM GENERATOR TESTING PROCEDURES

1.	Measure line pressure at manifold (should be between 114 and 200 psi)	(pressure)
2.	Set inductor into 5 gal of fresh water (should have tapered end with screen)	(check)
3.	Check foam inductor setting to ensure that it is locked into position 1 (other settings for different foam, not for different flow characteristics)	(setting)
		(locked in position)
4.	Start generator by simulating short circuit	(check)

#### **BRATTICE CURTAIN FOR FOAM GENERATOR**





UVERLAP MIN. 1 FT CURTAIN MATERIAL ON ROOF, FLOOR & RIBS

### MONTHLY SURFACE FIRE EXTINGUISHER CHECKLIST

STATION NO.	MAIN LOCATION	SUBLOCATION	ID	EXTINGUISHER NO.	SIZE	MFG	HYDROSTATICALLY TESTED	DATE	BY	COMMENTS

### BIANNUAL UNDERGROUND FIRE EXTINGUISHER CHECKLIST

COUNTER	LOCATION	MCC#	SIZE	MFG	HYDROSTATICALLY TESTED	DATE	COMMENTS

### **6-MONTH FIRE EXTINGUISHER INSPECTION**

#### 30 CFR 75.1100-3

- 1. Visual inspection
- a. Check for dents, rust, corrosion, welds.
- b. Check indicator button. If it is up, you must discharge any remaining pressure in a safe direction.
- 2. Remove  $CO_2$  cartridge weigh (must be within 0.25 oz of stamped weight).
- 3. Check rubber washer in  $CO_2$  cartridge seat. It must be intact and without cracks.
- 4. Check seal on  $CO_2$  cartridge, and make sure that it is not punctured.
- 5. Work puncture device to ensure smooth operation.
- 6. Open lid on cylinder and make sure that there is adequate chemical.
  - a. Add chemical, if necessary.
  - b. Work red indicator button up and down to ensure that it works properly.
  - c. Make sure rubber seal is in place on underside of lid.
- 7. Activate hose handle. Some chemical should come out of hose. If not, turn unit upside down and loosen chemical by pounding unit on cap board.

- 8. Once these steps are taken and everything checks out:
  - a. Place red tie around hose and through pin, tie a knot, and clamp on white Ansul clip.
  - b. Punch metal tag in appropriate spot. If tag is used up or missing, replace with a new one.
- 9. Then enter extinguisher number on the list, fill in appropriate date and location. Also, initial each row that you do.
- 10. If extinguisher has been discharged, it is immediately removed from service from that area and another fresh checked extinguisher will be placed there. The discharged extinguisher is taken outside to the foam generator where the hose is disconnected from the extinguisher and blown completely out by compressed air. The monoammonium phosphate is replaced, and a complete check is done on the extinguisher as stated above.

# **EXTINGUISHER MOUNTING LOCATIONS**

Equipment
-----------

#### Location

Track jeeps	On floor, trolley side between seats
Diesel mantrips - 6 man - 8 man - 4 man	Inside cab right side of transmission shifter Operator side rear fender well Inside cab right side of transmission shifter
Diesel trucks	Mounted to cab behind driver
Tugs	Left inside cab support leg in front of operator seat
Battery scoop	Operator side rear cubbyhole
Shield haulers	Left inside cab support leg in front of driver seat
Diesel scoop	Left inside cab support leg in front of driver seat
Diesel duster	Left inside cab support leg in front of driver seat
New style service center	Operator side behind cab mounted to grid steel
Old style service center	Cap support driver side front fender
Propane carts	Right-hand side opposite tank
Oxygen-acetylene carts	Back side of axle housing (horizontally)
Track roadmotors	Right inside rear wall of cab
NOTE: Bracket No. 40-03-0185	

### TRAILER-MOUNTED ANSUL 150C FIRE EXTINGUISHERS

- 1. Location:
  - a. Main North travelway between No. 2 and No. 3 entry at 46 and 61 crosscut and in No. 4 entry on MS travelway at 20 crosscut.
  - b. Surface locations: tipple, weld shop, between shop and compressor, and extras east of light-duty b
- 2. Consist of:
  - a. One cylinder holding 125 lb of Foray multipurpose dry-chemical agent
  - b. One nitrogen bottle
  - c. Hose with nozzle
  - d. One hitch used to move unit where needed

# FIREFIGHTING EQUIPMENT FIRE AUDIT REPORT

Date \_\_\_\_\_

Main location	Location	Condition	Comments	Checked by

# FIRST-AID SUPPLIES (EXAMPLE 1)

## FIRST-AID BOX CHECKLIST

Location	Date	Names_	
	Mir	imum quantity	Quantity needed
1-in by 3-in Band Aid	5	0 each	
Fingertip Band Aid	5	0 each	
Knuckle Band Aid	5	0 each	
2-in by 2-in bandage	8	(2 boxes)	
4-in by 4-in bandage	8	(8 boxes)	
24-in by 72-in bandage	1	each	
4-in by 6-yd dressing	1	each	
Triangular bandage	1	5 each	
Tourniquet	2	each	
Burn compound	1	box	
Ammonia inhalants	1	box	
Merthiolate	1	box	
Eye wash	2	boxes	
Ice pack	2	each	
Scissors	1	pair	
Таре	1	roll	
Disposable exam glove	2	each	
Folding stretcher	1	each	
Folding back board	1	each	
Spider straps	1	set	
Woolen blanket	2	each	
Disposable blanket	1	each	
Sam splints	2	each	
Board splints	1	set	
Air splints			
Full arm	2	each	
Full leg zippered	1	each	
Half leg zippered	1	each	
Sager traction splint	1	each	
Oral airway	1	set	
Non-rebreathing mask	1	each	
Pocket mask	1	each	
Oxygen mask	1	each	
Oxygen bottle/regulator/wrench	1	each	

Stiff neck collars	
Short	1
Regular 1 each	1
Fall         1 each	1
No-neck 1 each	1
Soft neck collars 1 each	1
3P cuff	1
Stethoscope 1 each	1
Glucose	1

\_\_\_\_\_

#### FIRST-AID SUPPLIES (EXAMPLE 2)

#### NOTICE

To help keep the large first-aid box adequately supplied at all times, we ask that you please obtain basic first supplies from this small first-aid box. Below is a "minimum quantity" list of the supplies contained in this s first-aid box. You may wish to add additional items. Please feel free to do so. If this box becomes deplete please bring it to the safety/facility technicians, who will either refill or replace.

#### SMALL FIRST-AID BOX SUPPLY LIST

M	linimum		Minimum
Item	quantity	Item	quantity
1-in by 3-in Bandits	50 each	Burn compound (Folie)	1 box
Fingertip Bandits	50 each	Merthiolate	1 box
Knuckle Bandits	50 each	Eye wash	2 boxes
2-in by 2-in bandage 8 (2	boxes)	Ice packs	2 each
4-in by 4-in bandage 2 (2	boxes)	Adhesive tape	1 roll or box

The idea here is to keep the large first-aid box properly supplied, clean, and organized for use in the event or critical emergency. For your reference, a list is attached to the outside of the large first-aid box identifying supplies it contains. Your cooperation is appreciated by all of your coworkers.

### **EMERGENCY MATERIAL SKIDS**

These skids are located at 30 crosscut MN TW and at 10 or 11 of section on the high side.

- 1. One skid to store and haul material
- 2. One chain used to help in hauling
- 3. 1,000 board ft of brattice board
- 4. Two rolls of brattice cloth
- 5. Two bow saws
- 6. Three claw hammers
- 7. 25 lb of 8d nails
- 8. 25 lb of 10d nails
- 9. 25 lb of 16d nails
- 10. Two shovels
- 11. One bundle of wedges
- 12. Twelve capboards
- 13. Four timbers
- 14. Five 5-gal buckets of Celtite (10 15c)
- 15. Four bags of rock dust
- 16. One ax
- 17. Six pogo sticks
- 18. One pointed trowel
- 19. One rectangular finishing trowel
- 20. One rectangular patching trowel

### FIRE AUDIT FORM

#### EMERGENCY MATERIALS CHECKLIST FOR FIRE TRAM

### DATE:

- () 112 Kennedy metal stopping panels with associated head sills and twist clamps
- () 24 Kennedy stopping rib angles
- () 3 rolls of tape
- () 3 twist tools
- () 3 stopping jacks
- () 3 picks
- () 3 shovels
- () 9 buckets of Celtite 10 12 Airtite (or equivalent material for stopping construction)
- ( ) 5 tons of rock dust

### SURFACE FIRE BRIGADE TRAILER CONTENTS

A utility trailer with a trailer hitch will be located east of the administration building. The trailer will contai following supplies and will be connected to an electrical receptacle to provide power to a heater and emerge light. The trailer is to be disconnected from the power source before moving it to the fire location. All sur vehicles, except the heavy equipment service truck, will have two 5/16 ball hitches for transporting the trailer addition, the 930 and 945 endloaders will be equipped to transport the trailer during inclement weather.

### **BREATHING APPARATUS**

- Four Draeger PA-80-4,500 1-hr breathing apparatus
- Five spare compressed air cylinders

### BUNKER GEAR

- 12 complete sets including fire repel firefighter coat and turnout bib pants, protective hood, firefighter g fire dome helmet
- 12 red carrying bags for bunker gear

### FIREFIGHTING EQUIPMENT

- 300 ft of 2.5-in NST fire hose
- 400 ft of 1.75-in IPT fire hose
- Two 25-ft rolls of 4-in supply line fire hose
- Three H-VPGI nozzles, 1.5-in IPT
- One H-VPGI nozzle, 2.5-in NST
- One flowmeter, 1.5-in IPT
- One Elkhart 241-95 in-line foam eductor
- Two 5-gal pails of multipurpose foam; additional foam is located in the warehouse
- Two-gated wye, 2.5 in to 1.5 in
- Seven fire extinguishers
  - Four 20-lb fire extinguishers One 30-lb fire extinguisher One  $CO_2$  fire extinguisher
  - One 150-lb wheel unit
- Four combination hydrant/spanner wrenches
- Six spanner wrenches
- One fire ax
- Two pike poles

- One hose clamp
- Four firefighting brooms
- Three water vests

### ONE 6,000-WATT WINCO GENERATOR

• Four 500-watt mounted quartz lights (outside trailer)

### ONE HAZMAT BOOK

#### FIRST-AID SUPPLIES

- One trauma kit
- First-aid kit
- One ked extrication device
- Four blankets

### TOOLS

- Two boxes of tools
- One 12-in crescent wrench for natural gas shutoff
- Three electric extension cords
- Regular wood saw
- Regular broom for cleaning trailer

#### UNDERGROUND FIRE BRIGADE SKID CONTENTS

#### **Firefighting Supplies**

#### Firefighting Supply Box

- 1. 1 each Three-way manifold (5-in Storz to 2.5-in NST)
- 2. 3 each Adapter (2.5-in NST to 1.5-in NPSH)
- 3. 1 each Adapter (5-in Storz to 4-in Victaulic fitting)
- 4. 1 each Vari-X foam generator
- 5. 1 each On/off valved pistol grip
- 6. 6 each 5-gal VEE foam buckets
- 7. 4 each Storz spanner wrenches
- 8. 2 each Task Force tip nozzles (one with pistol grip)
- 9. 2 each 1.5-in spanner wrench
- 10. Tools to open a stopping between the belt entry and the adjacent intake entry (**30 CFR 75.1103-9(a)(2)** requirement):

Claw hammer

Brass hammer

- 1 each Dutch head
- 1 each Ax
- 1 each Track Shovel
- 1 each Omega Block Saw
- 1 each 500-ft roll of 0.25-in rope
- 1 each tool bag with:

4-in screwdriver
6-in screwdriver
8-in crescent wrench
10-in crescent wrench
12-in crescent wrench
15-in crescent wrench
Hacksaw

S hooks 16 penny nails Rolls of tape Bucket lid opener

First-aid kit

• 2 each - 14-in pipe wrenches

#### *Fire Hose Box* (**30 CFR 75.1103-9(a)(1)** requirement):

- 1. 4 each 100-ft lengths hi-volume 5-in Storz fire hose
- 2. 2 each 25-ft lengths hi-volume 5-in Storz fire hose
- 3. 1 each 50-ft length hi-volume 5-in Storz fire hose
- 4. 12 each 50-ft lengths 1.75-in NPSH fire hose

#### **Open Storage**

- 1. 240 lb of rock dust (30 CFR 75.1103-9(a)(3) requirement) in six buckets
- 2. Two rolls thick curtain

## MATERIALS LIST FOR MINE RESCUE EMERGENCY

- **G** Mine rescue clothes and mine boots
- **G** Spare change of clothes
- G Hard hats
- **G** Mine belts with name tags
- **G** Cap lamps
- **G** Apparatus for each member and two spare apparatus
- **G** Extra canisters or BG4 training canisters with extra filters and DraegerSorb
- **G** RZ tester and tools
- **G** Spare part for apparatus
- **G** Antifog
- **G** Leak-Tec
- **G** Apparatus bench procedures manual
- G Turnout gear
- **G** Nomex gloves and hood
- **G** Firefighter helmet
- **G** Extra  $O_2$  bottles
- **G** Rescue rope and bands
- **G** Aprons with chalk
- **G** Thumping sticks
- **G** Hammers and nails
- **G** Spad guns
- **G** Spads and washers
- **G** Gas instrument
- **G** Chargers and extra batteries
- **G** Map boards with equipment
- **G** Two stretchers
- **G** Four fire extinguishers
- **G** Two blankets
- **G** One Exotecter
- **G** Two magnehelic gauges with tubing and pipe
- **G** Two sets of communication headphones
- **G** One 1,000-ft length of sound-powered cable with reel
- **G** One emergency procedures manual
- **G** EMT materials from competition list and two burn kits
- **G** One basket stretcher
- **G** Two mine rescue radios with batteries and chargers
- **G** Gas sampling bags, syringes, etc.
- **G** Rescue ropes and harness
- **G** Four fire lances

### SAFETY TRAILER LOCATIONS

### 1. Position of safety trailers

All safety trailers are located in the kitchen or x-cut across the kitchen. In the longwall, it is located in fron transformer. The only exception may be when a section is being developed, and the safety trailer will be for the Main travelway.

- 2. Contents of safety trailer
  - a. Five 100-ft fire hoses stored in a rack; some trailers have 55-gal barrels with 10- to 50-ft hoses
  - b. One 5121 Akron nozzle placed on end of last fire hose
  - c. One wheeled Ansul model 150 containing 125 lb of Foray multipurpose dry-chemical agent, one nitrogen bottle, and a hose with a nozzle
  - d. One hitch used to haul trailer
  - e. Four sets of bunker gear
  - f. One scoop stretcher
  - g. One portable potty
  - h. One first-aid box with oxygen
  - i. Twelve SCSRs in metal box

## FIRE PROTECTION AND FIREFIGHTING STANDARDS

#### 1. Foam generators

- a. Each mining complex shall have a trailer-mounted high-expansion foam generator stored on or nesurface.
- b. Each foam generator shall be equipped with 500 ft of #2 G-GC cable and is to have on hand anothe 1,500 ft of the same cable to reach remote power sources.
- c. Items to be stocked with the generator are:
  - 500 ft of 2.5-in fire hose with 2.5-in NH thread
  - 500 ft of 2-in fire hose with 2-in NPT threads and two nozzles with adaptors
  - A manifold with four 2-in NPT outlets for fire hoses or for the foam generator, with a 4-in by reducer (Victaulic)
  - Eight 4-in by 4-in by 10-ft posts
  - 1-in by 4-in lumber (or equivalent) (250 board ft)
  - Hammer and nails (8d, 16d, and roofing nails)
  - One roll of brattice
  - Spad gun, spads, and washers
  - Twenty 5-gal cans of foam concentrate
- 2. Firefighting storage stations
  - a. Per 30 CFR 75.1100-2(i), emergency materials that shall be stored, not exceeding 2 miles from e working section, are:
    - 1,000 board ft of brattice boards
    - Two rolls of brattice cloth
    - Two handsaws
    - 25 lb of 8d nails
    - 25 lb of 10d nails
    - 25 lb of 16d nails
    - Three claw hammers
    - 25 bags of wood fiber plaster or 10 bags of cement (or equivalent material for stoppings)
    - 5 tons of rock dust

The following items shall be stored at central warehouse, boxed and ready:

- 500 board ft of 1-in lumber
- Three spad guns
- One can of spads
- One box spad washers
- One box 16d nails
- One box 8d nails
- Six carpenter hammers
- Six rolls brattice
- Six boxes rigipak foam
- Three axes
- Three handsaws
- Twenty-four 4-in by 4-in adjustable posts with bolts and nuts
- Five 100-ft lengths of 2-in fire hose with 2-in NPT threads
- Two fire nozzles
- Ten roof jacks, ratchet-type aluminum
- Four shovels
- 300 framing boards, 1 in by 4 in by 10 ft (or equivalent) (1,000 board ft)
- One bundle each cap pieces and wedges
- Four 30-lb fire extinguishers
- Two 10-lb sledge hammers
- Two trimming bars
- One pick
- Four 2-in fire hydrants
- One 24-hr supply of high-expansion foam
- b. The following items shall be stored at each mine on the surface, boxed and ready:
  - Five 100-ft lengths of 2-in fire hose with 2-in NPT threads
  - Two fire nozzles
  - One spad gun
  - One box spad washers
  - Two claw hammers
  - One box 8d nails
  - One box 16d nails
  - One ax
  - Two rolls brattice
  - Two 30-lb fire extinguishers
  - Two 1.5-in pipe nipples
  - Two 2-in pipe nipples
  - Two 2-in to 1.5-in bell reducers
  - Two large water pump pliers

- One 2-in fire hydrant valve
- Two 12-in pipe wrenches
- One scaling bar
- Two pocket knives
- One pick
- Four 2-in fire hydrants
- One manifold with four 2-in outlets

Emergency material to be kept on each miner section:

- Two portable fire extinguishers (20 lb minimum)
- 240 lb of rock dust
- Water lines extended to section loading point (tailpiece) with enough hose (500 ft minimum) reach each face

## FIRE PREVENTION EQUIPMENT CHECKLIST

## Fire Prevention Equipment Checklist

Emergency sled	700 ft of fire hose with nozzle
	Vari-X foam generator and eductor
	Three buckets of foam concentrate
	Two rolls of brattice cloth
	Two boxes of nails (6p and 8p)
	12 or more SCSRs
	Emergency escape map
Oil station	Five bags of rock dust
	One 10-lb fire extinguisher
	Area well dusted and free of trash
Power center	Five bags of rock dust
	One 100-lb fire extinguisher
	Area well dusted and free of trash
Water pump	Five bags of rock dust
	One 10-lb fire extinguisher
	Area well dusted and free of trash
Feeder	Controls and pump area clean, free of oil and oil-soaked coal dust
	Fire suppression system intact
	<u>Machine and tailpiece free of excessive accumulations of</u>
	coal dust and/or spillage
Dinner hole/	Area well dusted and free of trash
repair wagon	One fire extinguisher
	Compressed gas cylinders stored correctly and secured
	Remote fire suppression operative
Continuous miner	Remote fire suppression operative
	Manual fire suppression operative
	Hose for a hose fire suppression operative (if available)
	Miner clean, no oil or oil-soaked coal accumulations
	Fire nozzle and adapter stored on miner
	Operator has methane spotter and is making proper checks

Roof bolter	Fire suppression system intact Bolter clean and free of oil or oil-soaked coal Operator has methane spotter and is making proper checks		
Coal haulers			
Unit #			
<u> </u>	Fire suppression system intact		
<u> </u>	Hauler clean, free of oil and oil-soaked coal		
<u> </u>	SCSR OK		
Scoop	<ul> <li>Fire suppression system intact</li> <li>Scoop clean, free of oil and oil-soaked coal</li> <li>Operator has methane spotter and is making proper checks</li> <li>SCSR OK</li> </ul>		
Belt	<ul> <li>Two 20-lb fire extinguishers at drive area</li> <li>Five bags of rock dust at the starter box</li> <li>Five bags of rock dust at the take-up</li> <li>One 10-lb fire extinguisher at the take-up</li> <li>Drive clean and free of coal and oil accumulations</li> <li>Fire sensor system tested and operative</li> <li>Fire deluge system intact</li> </ul>		
	Fire sensors every 125 ft along beltline		
	Fire outlets located every 500 ft or less along beltline		

Req. By: Run on:	at:	Page: Report:
	Stand Alone PM	Version:
JOB CARD FOR TA 7-DAY INSPECTIO	ASK NUMBER E001 DN MSHA REQUIREMENT	
WORK GROUP: EQUIPMENT NUM	/BER:	
RESOURCE TYPE	NO. REQUIRED EST. HOURS	
"	DATES	
LAST SCHEDULE	DATE LAST PERFORMED DATE NEXT SCHEDULE DATE JOB PRIORITY COMPONENT MODIFIER SEQUENCE	MAINTENANCE TYPE
	COMPI ETION TEXT	
	IOB INSTRUCTIONS	
ELECTRICAL NECESSARY MAT 07 DAY INSPECTI DATE DUE: CALIBRATED BY:	'ERIALS: CO CALIBRATION KIT ION NEXT DUE DATE: : DATE:	
1. INFORM SECU AND SHIFT FO MINE-WIDE AI A. INFORM TI YOU WILL	RITY, WORKING SECTIONS, BELT PEOPLE, PREMAN THAT YOU WILL BE CREATING A LARM FOR TESTING PURPOSES ONLY HEM OF AN APPROXIMATE TIME THAT PERFORM THE TEST.	
2. PICK A BELT C IDENTIFY TO 2	CO ANYWHERE UNDERGROUND, BUT DO NOT SECURITY WHAT THAT CO IS	
3. APPLY CO GA	S TO START MINE-WIDE ALARM	
4. CALL SECURIT MINE-WIDE AI ORIGINATED. THE TEST WAS	ГҮ AND ASK IF THEY RECEIVED A LARM AND FROM WHERE THE ALARM IF SECURITY ANSWERS CORRECTLY S A SUCCESS.	
5. ** IMPORTAN THE CONSPEC BOOK IS ON T	T ** HAVE SECURITY ENTER IT IN WEEKLY FUNCTIONAL TEST BOOK HE SHELF JUST ABOVE THE CONSPEC	

# FUNCTIONAL TEST OF MINE MONITORING SYSTEMS

PRINTER. MAKE SURE THEY SIGN IT, ALSO.

ADDITIONAL COMMENTS: \_\_\_\_\_

=

REVIEWED BY: \_\_\_\_\_ DATE \_\_\_\_\_

\_\_\_\_\_

DATE	LOCATION	STATUS	INITIALS

# WEEKLY CONSPEC SYSTEM FUNCTIONAL TEST

	DATE	INSPECTED BY:
CHECK POINTS	STATUS	COMMENTS:
ISOLATOR BOX BLINKING	YES - NO	
ACC STATS/TRUNK 1 AND 2	YES - NO	
PAPER IN PRINTER	YES - NO	
SEQUENCE MONITOR FLASHING	YES - NO	
TIME AND DATE ON LISTING	YES - NO	
POWER UN	IIT	
AC - READY - CHARGER LIGHTS ON	YES - NO	
INVERTER AND ALARM LIGHTS OFF	YES - NO	
VOICE ALARM WORKING	YES - NO	
DISPLAY AND OPERATING CHECKS	YES - NO	
CO'S CHANGING TRUNK 1 - NINE RIGHT	YES - NO	
CO'S CHANGING TRUNK 2 - THIRD SW	YES - NO	
CLEAR BUFFER SCREEN	YES	
INVESTIGATE AI	LL NO'S!	
NOTES		

# MINE MONITOR INSPECTION REPORT

NAME: \_\_\_\_\_DATE: \_\_\_\_\_

# CONSPEC EMERGENCY COMMUNICATION CENTER ACTIVITY LOG

	COMMENTS:
TIME:	
READINGS:	
LOCATIONS:	
TIME:	
READINGS:	
LOCATIONS:	
TIME:	
READINGS:	
LOCATIONS:	
TIME:	
READINGS:	
LOCATIONS:	
TIME:	
READINGS:	
LOCATIONS:	

# CONSPEC ROOM CALLOUT LOG

DATE	SECTION	WHO	TIME	STATUS	PED SYSTEM CALL NO.	INITIALS

## CUTTING/WELDING PERMIT (EXAMPLE 1)

#### CUTTING/WELDING OPERATIONS

Hot work permit

- 1. Call communication coordinator
- 2. Methane check: every 20 min
- 3. Rock dust before starting
- 4. 10-lb fire extinguisher or 240 lb rock dust
- 5. Blankets to cover area, surface only
- 6. Protective equipment
- 7. Long sleeves or weldingleathers
- 8. Welding gloves
- 9. Safety glasses
- 10. Welding hood: check for holes, cracks in lens
- 11. Cutting goggles: check forbroken lenses
- 12. Leg bands or cuffs tied

#### ADDITIONAL SAFETY CHECKS

- 1. Examine work area for:
  - a. Stumbling hazards
  - b. Unsafe roof conditions
  - c. Adequate ventilation coursed to return
  - d. Cleanliness: grease, oil, coal dust removed
- 2. Ground clamp secured
- 3. Inspect equipment before using: torch, welder, etc.
- 4. Warn others before striking an arc
- 5. When welding overhead-protect ears with nonflammable material
- 6. Do not gob hot material

### **CLOSE-OUT INSPECTION - 1 HOUR**

- 1. Inspection date: \_\_\_\_\_\_
- 2. Inspected by: \_\_\_\_\_\_.
- 3. Conditions found: \_\_\_\_\_
- 4. Call communications coordinator to inform of followup inspection
- 5. Turn in tag to shift manager or preparation plant supervisor (surface).

## **CUTTING/WELDING PERMIT (EXAMPLE 2)**

#### HOT WORK PERMIT

*Note:* Before issuing this permit, all of the precautions described in company SOP should be followed.

I have been instructed, and I understand the hazards, as well as the precautions necessary to do this work.

Signature of person performing work		
I verify that the work site has been inspected, all		
prevent fire, and the individual who has signed above is authorized to do this work.		
Signature of supervisor		
Date and time of signature		
C C		
- 1. Have all flammable or combustible materials been removed from the work area (35-ft radius)? Yes □ No □
- 2. If any flammables or combustibles cannot be removed, have they been properly covered by fire-resistive shields or tarpaulins? Yes No
- 3. Are fire extinguishing systems in service? Yes No □
- 4. Are adequate portable fire extinguishers and/or hoses provided? Yes  $\square$  No  $\square$
- 5. Have combustible floors or roofs been wet down and/or properly covered? Yes No
- 6. Have wall or floor openings been properly covered? Yes  $\square$  No  $\square$
- 7. Is hot work equipment in good working condition? Yes □ No □
- 8. Is a confined space permit required? Yes 🗆 No 🗖
- 9. Is a line breaking permit required? Yes  $\square$  No
- 10. Is lockout/tagout required? Yes  $\Box$  No  $\Box$
- 11. Has the atmosphere been checked with a combustible gas detector? Yes □ No □
- 12. Is ventilation adequate? Yes  $\Box$  No  $\Box$
- 13. Is adequate PPE provided (glasses, mask, gloves, breathing apparatus)? Yes □ No □

Work completed \_\_\_\_\_

Date/time

I have inspected the worksite after completion of the work and find the area to be in safe condition.

Signature of supervisor

Date and time of signature

## SPECIFICATIONS FOR SLOPE WATER LINE

## PERFORMANCE

The slope water line system shall deliver 50 gpm to each of three hydrants. The pipeline shall be drained after each use and normally kept empty to prevent freezing. Water shall be introduced via an electrically operated valve that can be locally (coal seam at surge bin) or remotely (Communications-Warehouse) actuated. The drain valve shall be interlocked with the supply valve and must be closed prior to opening the supply valve. There will be local and remote indication of valve positions. The supply and drain valve shall have manual override of electrical actuator.

## MATERIAL SPECIFICATIONS

Pipeline

Three-inch nominal diameter aluminum pipe schedule 40 furnished in 20-ft lengths with grooved Victaulic style 77 couplers.

#### Supports

Pipeline shall be supported at least every 10 ft. An additional support shall be provided at each tee. The support shall consist of a fiberglass Enduro Model #SR1-9P furnished by Westfall Co. The support shall be secured to the concrete wall with two 3/8-in-diam "red-head" studs, stainless steel type.

Use a pipe clamp on each support. Clamp to be Model #PC-1617N.

## Supply and Drain Valve

The supply valve shall be 3-in Trivaco MAK150 SG07-M. Adams Class 300 rotary tight shutoff valve. Rated for 210 psi. CS double flanged body, 3156 SS Disc and seat. NI Resist pressed bearings, and zero leakage. It shall be actuated by 115 v AUMA SG07 Quarter-turn actuator complete with water-tight enclosure.

The drain valve shall be a nominal 1-in 110 v, SS construction, normally open. Similar to McMaster Carr 4665K46, page 1428, catalog 100.

## Air Release Valve and Vacuum Breaker

The air release valve shall be C.I. 1-in by 0.5-in similar to McMaster Carr 48045K73, page 1438, catalog 100, 50 XI S.

The vacuum breaker shall be 1.5 in by 1.25 in similar to McMaster Carr 4817K28, page 1429, catalog 100.

## Water Tee

The tee shall be Victaulic style 72 - 3 in by 1.5 in.

The angle valve shall be rough brass 1.5 in UL 175# fire line angle valve.

#### SPRINKLER SYSTEM FOR FREEZING AND NONFREEZING LOCATIONS



#### GENERAL NOTES

- 1. All water pipes 2 in (schedule 40) metal pipe, except as noted.
- 2. All pipe fittings malleable iron 300 lb. Extra heavy or equal.
- 3. Attach pipe to permit expansion movement.
- 4. If sprinkler is too low to have water discharge over belt, rotate pipe enough to get coverage. Flow test to adjust for proper tilt.
- 5. For freezing areas, system requires a 50/50 mixture of antifreeze (ethylene-glycol). To determine gallons required for 2-in pipe, multiply total number of feet (pipe in system) by 0.18, then divide by 2; this equals gallons of antifreeze.
- 6. 50-ft minimum at belt drive with fire-retardant belt. 150 ft minimum at belt drive without fire-retardant belt.
- 7. Optional 2-in outlet provided for optional 2-in hose connection to extend to remote head roller sprinklers.
- 8. Pipe may be mounted at any height. Uprights shall be installed to maintain sprinklers near the roof.

## ELECTRICAL NOTES

- A. Contacts of item No. 3 to be wired in stop circuit of belt drive motor starter.
- B. Contacts of item No. 3 to be wired to fire detection system or audible visual alarm system.

## KEY

- 1. 2-in ball valve class 300 FM approved or UL listed; pressure rating as required.
- 2. Ball valve class 300 FM approved or UL listed; pressure rating as required.
- 3. Waterflow switch FM approved or UL listed; pressure rating as required.
- 4. Sprinkler pendant type FM approved or UL listed; 0.5-in orifice, 212E F temperature rating.
- 5. Sprinkler Upright type FM approved or UL listed; 0.5-in orifice, 212E F temperature rating.
- 6. Pipe plug (optional 2-in outlet for headroller protection).
- 7. Valve swing check 2-in class 300 or equal (freezing areas only).
- 8. Reducing tee 2 in by 2 in by 0.5 in malleable iron extra heavy or equal.

#### SUPPRESSION SYSTEM

#### MAINTENANCE - SEMIANNUAL EXAMINATION

To provide maximum assurance that your Ansul A-101 system will operate effectively and safely:

- 1. Note the general appearance of the dry-chemical tank for mechanical damage or corrosion.
- 2. Check nameplate for readability, corrosion, or looseness.
- 3. Remove fill cap.
- 4. Examine fill cap gaskets for elasticity. Clean and coat lightly with a good grade of high-resistant grease.
- 5. Inspect threads on fill cap and in fill opening for nicks, burrs, cross-threading, rough or feathered edges.
- 6. Check pressure relief vent in fill opening threads for obstruction.
- 7. Make certain tank is filled with free-flowing Ansul Foray dry chemical to a level of not more than 3 inches from bottom of fill opening.
- 8. Secure fill cap, hand tighten.
- 9. Disengage bursting disc union.
- 10. Examine the bursting disc. If necessary, move the tank slightly to view disc. The bursting disc should be properly seated with the washer side facing out (smooth side in) and should be undamaged (smooth, not scored or ruptured).
- 11. Engage bursting disc union (wrench tighten). *CAUTION:* Overtightening can damage bursting disc.
- 12. Loosen the bolt(s) that restrain the cartridge or remove extinguisher cartridge guard assembly.
- 13. Inspect the expellant gas cartridge assembly for evidence of mechanical damage or corrosion.
- 14. Unscrew the cartridge from the pneumatic actuator/cartridge receiver and weigh it. Replace if its weight is not within specifications stamped on the cartridge.

- 15. Inspect threads on cartridge and in pneumatic actuator/cartridge receiver for nicks, burrs, cross-threading rough or feathered.
- 16. Check pressure vent in pneumatic actuator/cartridge receiver for obstruction.
- 17. Examine cartridge receiver gasket for elasticity. Clean and coat lightly with a good grade of high heat-resistant grease. Return cartridge pneumatic actuator/cartridge receiver, hand tighten.
- 18. Tighten the bracket bolt(s) uniformly or return cartridge guard assembly.
- 19. Be sure the dry-chemical tank is firmly mounted in its bracket.
- 20. Check hose, fittings, and nozzles for mechanical damage.
- 21. Check nozzle openings. Slot should be closed (capped) with silicone grease or covered with plastic blowoff cap.
- 22. Check remote actuator. Remove cartridge and weigh (replace if weight is 0.25 oz less than stamped on cartridge). Inspect threads on cartridge and in actuator for nicks, burrs, cross-threading, rough or feathered edges. Check pressure safety vent in actuator body for obstruction. Examine actuator cartridge gasket for elasticity. Clean and coat lightly with a good grade of high heat-resistant grease. Pull ring pin and operate actuator button several times to check for free movement.
- 23. Seal ring pin to puncture lever with lead and wire seal. Return cartridge to remote actuator, hand tighten.
- 24. Record date of maintenance.

## ANNUAL FUNCTIONAL TEST OF THE FIRE SUPPRESSION AT BELT DRIVES

30 CFR 75.1107-16(b)

This test is done to make sure that:

- 1. Water flows through each branch line in the system.
  - a. The last spray in each branch line of the fire suppression system has a tee with the spray pointed toward the belt. The other side of the tee has a ball valve. This ball valve allows testing to be done without using tools.
  - b. The ball valve may be at the end of the branch line and not hooked to a spray or tee. The same results will take place when testing.
- 2. When the ball valve is opened and water is flowing, the belt should shut off and the alarm will automatically be activated on the computer in the guard shack.
- 3. If any of these results are not obtained, correction shall be made at once, and the Safety Department is notified of shortcoming.

TYPICAL LANCES



# INDIVIDUAL WORK HAZARD ASSESSMENT

Name	Date			Shift	Crew
Return at end of shift					
Protective Equipment Checklist					
Metatarsal safety shoes/hard hat?		1	Mandator	У	
Safety glasses?	M	andato	ory		
Hearing protection needed?	Y	es	No		
Gloves or respirator needed?	Y	es	No		
Cutting goggles/welding hood needed	d? Ye	es	No		
Fall protection required?		, second se	Yes	No	
Ice grips or life vest needed?	Y	es	No		
Preoperational Equipment Inspection	1				
Equipment type:	Ec	quipme	ent #:		
Substandard conditions observed, but	ut not corrected (desc	ribe):			
Was a work order generated to corre	ect these conditions?		Yes	No	
Work Area Inspection					
Substandard conditions observed, but	ut not corrected (desc	ribe):			
Were these conditions reported to a	supervisor?		Yes	No	
	*				
Job Safety Analysis (JSA)					
Work task(s) performed:					

Does a JSA exist for task(s) perform	ned?	Yes	No		
Was the JSA reviewed? Yes No					
Was an "individual" JSA developed for task? Yes No (see details on next page)					
Fls:	Smm:		Supt:		
Time reviewed:	Time reviewed:		Time reviewed:		

Daily Work Assignments

Ľ Ú	ndividual" Job Safety Analysis		
Job:	Location:		
Sequence of Basic Job Steps	Sequence of BasicPotential AccidentsRecommended SJob Stepsor HazardsProcedur		

# BELTLINE INSPECTION CHECKLIST

Date:		Shift
Belt No	)	
	Ι	Date
OK	Defective Re	epaired
		Stoppings
		Doors
		Guards
		Cross-overs/unders
		Dust
		Roof/rib Conditions
		Belt idlers
		Drive/Take-ups
		Splices/wipes accumulations
		Trash/coal accumulations
		Wire/electrical
		Fire sensors
		Fire line
		Risers/valves
		Fire hose/nozzles
		Water sprays
		Fire suppression
		Extinguisher
		Ventilation
		Phones
		Welds/tie-downs
		Walkways
		Belt bank or take-up pressure
		Belt training

Examiners:
Corrected by:
Routing list: Belt Crew Down Shift Supervisor File

# SCSR CHECK SHEET

## MEMO

Need to check your crew's SCSRs and fill out the form attached.

Information needed:

Name:

SCSR No.:

SCSR date:

Need this done and turned in to Safety by \_\_\_\_\_

Date

Name	SCSR No.	Manufacturer date

 1	

# DAILY SCSR EXAMINATIONS

DATE: \_\_\_\_\_

LOCATION	SCSRs	EXAMINED BY	LOCATION	SCSRs	EXAMINED BY	LOCATION	SCSRs	EXAMINED BY
								┞─┼───

## APPENDIX C.—EXAMPLES OF RESPONSE PLANS AND TRAINING PROGRAMS

#### MINE EMERGENCY OPERATION PLAN

MEO Plan

COMMAND CENTER

#### EMERGENCY COMMAND CENTER CHAIRMAN ACTION DIRECTOR EXECUTIVE OFFICER EXECUTIVE OFFICER MEO COORDINATOR COMMAND CENTER CLERK INFORMATION OFFICER L.U. REPRESENTATIVE SENIOR MSHA OFFICIAL **MSHA** SENIOR IDMM OFFICIAL **IDMM** UNDERGROUND SURFACE MAINTENANCE PUBLIC EMERGENCY EMERGENCY RELATIONS TASK TASK TASK COORDINATOR TASK COORDINATOR TASK COORDINATOR TASK COORDINATOR BACKUP BACKUP BACKLIP BACKUP MEDICAL/SAFETY SUPPLY SUPPORT TASK SERVICES TASK TASK TASK COORDINATOR TASK COORDINATOR TASK COORDINATOR BACKUP BACKUP BACKUP

#### COMMAND STRUCTURE

## COMMAND STRUCTURE



SONNEL ASSIGNMENTS AND RESPONSIBILITIES

#### FIRST RESPONDER

- C Notifies Communications/Tech-Staff Warehouse of potential problem and to be on alert.
- C Post a person, if available, just outby the area to act as a sentry to:
  - Keep persons from inadvertently entering a dangerous area.
  - Log activities (for example, people evaluating area, firefighting, etc.)
  - Assist in notifying Communications.
  - Be available to respond to helping first responder in case of a problem (for example, smoke inhalation

- Investigates to confirm evidence of fire/smoke (visual) and makes judgment on severity of situation.
  - If it is a small fire that can be extinguished, attempt to extinguish fire using appropriate safety precautions and existing safety equipment.
  - If the fire is so large that efforts to control are not working, then return back to sentry and notify communications to begin orderly evacuation of persons inby fire area. Give Communications/Tech-Staff Warehouse directions as to which escape route is safest and fastest.
- C Notifies appropriate personnel to shut off conveyor belts and/or kill power in affected area, if needed.
- C First responder remains at the site to assist in evacuation and, with help of the sentry, maintains constant communication with Communications/Tech-Staff Warehouse on status of fire and evacuation of potential problems.

#### COMMUNICATIONS

C Immediately notifies Fire Detection Team and alerts available Fire Brigade members if source of smoke is not apparent.

Fire Detection Team: Shift Mine Manager; Safety Personnel; Maintenance Foreman; and Safety Committeeman

- C If problem cannot be controlled by the first responder, the Communications/Tech-Staff Warehouse will dispatch the Fire Brigade to the area.
- C Communications/Tech-Staff Warehouse immediately dispatches Top Shop Repairman (or ?) to Water Treatment Building to deactivate excess flow valve switch (located in northeast corner of building to right of breaker box). Switch must be turned from "remote" to "local." Ensure valve is open to fullest extent by manually pulling bypass valve wheel out 3/8 inches and rotating counterclockwise as far as possible. The valve is located in lower level of the Water Treatment Building.
- C Top Shop Repairman should then be directed to Smith Lake Pump Station to ensure and maintain function of water pumps.

## MEO Plan

- C Immediately notifies all underground areas of the problem. If necessary, begins evacuation of all personnel in affected areas and receives information on possible evacuation routes.
- C Notifies Mine Superintendent, Construction Coordinator/Operations Support, and Longwall Coordinator if a severe problem is found.
- C Contacts all surface foremen to come to Communications Center.
- C Shift Mine Manager informs Communications/Tech-Staff Warehouse to assign lamp man and/or one surface foreman to count and check off evacuated personnel and double check the check-in/check-out tag system
- C Assigns one Warehouse Clerk to remain with the Communications/Tech-Staff Warehouse to help answer/make phone calls.

Warehouse Clerk - Primary Surface Foreman - Backup Designee out of Labor Pool

- C Establish initial security at surface-controlled access locations by utilizing available Surface Foremen, Underground Foremen, or any available employees. Secures Mine Examiners Books from the Examiners Room and Visitors Log Book from the old Training Room.
- C Sees that subsequent events and communications are noted with respective times in the Fire/Smoke log.
- C Calls ambulance to be on-site for possible injuries resulting from fire or evacuation of mine.

## UNDERGROUND EMERGENCY

SMOKE AND FIRE LOG
Name of Person(s) Reporting
Times
C First discovered
C First reported
C All subsequent information
Location of Discovery
C Main, submain, and/or panel
C Intake, neutral, and/or return
C Entry number(s)
C Crosscut number(s)
Source of Smoke/Fire
C Actual source, if known
C Source inby/outby discovery location
C Smoke/fire traveling inby or outby
Extent of Smoke/Fire
C Smoke/fire detected by smell only
C Smoke/fire visible
C Visibility in feet
C Entry numbers affected
Any Other Pertinent Facts
C Extent of efforts to extinguish
C No. of people working in the area
C No. of people working inby area
C Active projects in the area
C Is equipment deenergized?
C Problems that may affect ability to evacuate inby personnel

## MEO Plan

#### FIRST-LINE SUPERVISOR (OR PERSON IN CHARGE)

- C Secure work area:
  - Designate employee to monitor phone.
  - Shut off unit power and water.
  - Assemble entire crew.
- If time permits:
  - Back out all equipment outby last open crosscut.
  - Hang all ventilation curtains.
- C Prepare for evacuation:
  - Communicate all known facts to crew, emphasizing a safe, calm evacuation.
  - Distribute SCSRs.
  - Obtain escapeway map.
  - Notify Communications/Tech-Staff Warehouse that work area is secure and report any status change.
- C Evacuation:
  - Determine evacuation route based on all available information from Communications/Tech-Staff Warehouse and first responder. *Keep your crew together*.
  - Notify Communications/Tech-Staff Warehouse of departure time, names, and route.
  - Proceed to surface via designated escape route (call out location, if route has telephones.)
  - First supervisor on mine bottom helps coordinate caging of employees to surface and records name of those leaving the mine.
  - Other supervisors assign transportation to send in additional equipment and people as requested.

#### RESPONSIBILITIES OF FIRST SUPERVISOR ON SURFACE

- C Check off persons exiting the mine and persons already on surface.
- C Ensures that persons who have exited mine have "checked out" on the board.
- C Assemble workers and maintain order in waiting area.
- C Ensures that persons entering mine are logged in.

## OPERATIONS CHECK-IN/CHECK-OUT PROCEDURES

- C The Shift Mine Manager is responsible to see that Check-In/Check-Out Procedures are initiated during an emergency mine evacuation. He/she will designate two first-line supervisors to coordinate caging and check-in/check-out from the mine.
- C The standard "Check-In/Check-Out Log" form will be used to document all activities by recording the name, affiliation, social security number, tag number, and time for anyone entering or leaving the mine.
- C The Check-In/Check-Out Official will be notified of the mine emergency by the Shift Mine Manager. This official will report to the mine and confirm the following:
  - A first-line supervisor is stationed at each portal.
  - A positive Check-In/Check-Out System is in place at each portal to restrict access into the mine and to document the exit of personnel.
  - All information is being documented on the "Check-in/Check-Out Log" form by the first-line supervisor and sufficient forms are available.
- C The Check-In/Check-Out Official must also:
  - Obtain a list from Operations or Payroll of all personnel who were in the mine prior to the emergency
  - Based on this information and Check-In/Check-Out Logs, determine which personnel are still in the r
  - Provide all appropriate information to the Shift Mine Manager.
  - If necessary, set up a rotation schedule for first-line supervisors monitoring check-in and check-out at portals.
  - Arrange for a guard from the labor pool to guard the slope entrance.

#### SHIFT MINE MANAGER/MAINTENANCE FOREMAN

- C Firefighting Brigade Mobilization:
  - Team members proceed to site of fire, taking fire brigade equipment from area storage.
  - Arrive at site, evaluate situation, and put on appropriate protective gear.
  - Devise plan of attack and outline any materials/equipment needed, and relay this information to Communications/Tech-Staff Warehouse. Also, request any extra people/equipment needed.
  - Kill all power at fire site and inby fire area, lock out the trolley power outby the fire area. Station someone at this point, and do not let other people inby this point unless they are associated with the fire brigade.
  - Decide within 15 min on the scene whether to call mine rescue team members and fire brigade members on other shifts for backup.

## MEO Plan

#### OTHER ACTIONS

#### SURFACE

- C Surface fire brigade members are notified to get the fire brigade equipment trailer and bring it to the elevator so that equipment bags can be sent underground.
- C Safety department personnel get all necessary carbon monoxide (CO) detectors, modified sampling pumps, and sample tubing from their office. Additional handheld radios from Communications Center are also acquired. This equipment is to be taken/sent underground to fire site:
  - Prepares first-aid area for any reported injuries.
  - Sees that procedures are followed for notifying regulatory agencies.

#### FIREFIGHTING GUIDELINES

- C Initial response to a significant mine fire event:
  - CO and methane gas levels must be monitored in the fire area, return, and intake to the fire area. CO 10 ppm: indication of a fire
    - 50 ppm: irrespirable atmosphere
  - Using modified sampling pumps or protective breathing apparatus to determine CO reading in the return. *Do not adjust ventilation to the fire site*. Take CO and methane readings every 15 min and set up sampling pumps, if prolonged effort is envisioned.
  - Notify the Communications/Tech-Staff Warehouse if extra air tanks are needed or if refilling of air tanks is needed, and set up delivery system.
  - Have warehouse send foam generators and additional foam, if needed.
- C If firefighting actions exceed 15 min:
  - Send top shop repairman to exhaust fan for monitoring. Send modified sampling pump, CO and methane detector to fan with one underground foreman. Monitor exhaust fan readings every 15 min and report readings to Communications/Tech-Staff Warehouse.
  - Send one underground foreman to gate and control access until the Mine Emergency Organization is operating.
  - Send one repairman and underground foreman with pager phone from warehouse to locked out power switches. Establish communications with Communications/Tech-Staff Warehouse.
  - Send one foreman to the Communications Ccenter to specifically log all firefighting activities and respective times.

## **EMERGENCY RESPONSE (EXAMPLE 1)**

## A. FIREFIGHTING AND EVACUATION PROCEDURES INBY FIRE AREA

If a fire occurs or is suspected (i.e., alarm(s)) outby the working section, all personnel who are inby the fire area shall be immediately withdrawn to a point outby the fire area, at which time they will be assigned to firefighting activities or be withdrawn from the mine.

The supervisor inby the fire area should:

- 1. Be in charge of the evacuation of those persons under his/her charge.
- 2. Account for all persons within his/her respective area.
- 3. Designate the escape route to be taken and notify the responsible person on the surface that an evacuation is underway and the escape route to be used.
- 4. The supervisor or his/her designee will check at frequent intervals at mandoors to see if the fire area has been passed, if the fire area is unknown at the time of evacuation.
- 5. When the fire area is passed, leave the emergency equipment in an accessible location.
- 6. In the event that escape is impossible, the crew will travel to an area that can be safely barricaded. The following procedures should be followed:
  - (i) Note outside of the barricade the number of persons and what time the barricade was entered.
  - (ii) Inside the barricade conserve food and water.
  - (iii) Conserve battery lights by using only one at a time, and conserve air by remaining inactive.
  - (iv) Circulate the air occasionally by having one person walk back and forth with their coat extended.
  - (v) One person should pound on a pipe, belt structure, roof bolt, rail, or other sound conductor at 15-min intervals to alert rescue crew(s) as to the location of the barricade.

7. Supervise the evacuation and see that the following assignments are carried out:

Miner section	Longwall section	Personnel assignments
Mechanic	Mechanic	Assist Supervisor(s)
Miner Operator	Shearer Operator	First-aid supplies
Miner Operator	Shearer Operator	Hammer and nails
Roof Bolter	Cornerman	Saw and ax(es)
Roof Bolter	Laborers	Spads and spad gun
Shuttle Car Operator	Propman	Brattice cloth
Shuttle Car Operator	Propman	Brattice cloth
Faceman	Faceman	Account for and distribute SCSRs and see that each person has his/her lunch bucket.

## PERSONNEL ASSIGNMENTS FOR WORKING SECTIONS INBY A FIRE

## **B.GENERAL FIREFIGHTING PROCEDURES**

It is recognized that the majority of mine fires are not of major proportions and can be readily brought under control. However, the seriousness that could develop must be considered with a predetermined plan for firefighting and evacuation of underground mine personnel.

The following procedures should be followed in the event of a mine fire:

- 1. If a fire is found or suspected, immediate action shall be taken to find and correct the cause, and the requirements regarding notification shall be implemented immediately.
- 2. Firefighting activities shall be started as soon as possible and continued until the fire is extinguished or until it cannot be safely controlled.
- 3. All electric power shall be deenergized in areas affected when posing a hazard to individuals in that a
- 4. Maintain control of and know the location of all persons in the fire area, and remove those not required for firefighting activities.

- 5. A carbon monoxide detection instrument shall be transported to the fire area and sampling started as soon as possible.
- 6. Always attack the fire from the smoke-free side, if possible.
- 7. Never use water on an electrical fire until the power is deenergized.

## FIRE DRILLS

All miners shall participate in fire drills in accordance with 30 CFR 75.1101-23(c).

#### A. TYPE OF TRAINING

1. Various types of training may constitute a fire drill (for example, demonstrations, hands-on training, group discussions, and task-oriented training).

#### ESCAPEWAYS

The following shall apply with regard to escapeways:

#### A. ROUTES OF TRAVEL

1. Main escapeway systems and working section escapeways shall be reviewed with all miners in accordance with 30 CFR 75.383(a) and (b).

#### B. ESCAPEWAY MAPS

1. Posting of maps showing the main escapeway system and working section escapeways shall comply with 30 CFR 75.383(a).

#### C. LIFELINES

1. A lifeline will be made available in each working section at or near the SCSR storage cache for use by the section crew in the event of an emergency. The lifeline will have hookups at no more than every 7 ft. If tag lines are used, they should be no longer than 3 ft.

## **EMERGENCY RESPONSE (EXAMPLE 2)**

#### GENERAL SURFACE FOREMAN

- 1. Shall go immediately to the mine monitor room, see that the on-site notification plan is in progress, and ensure that all crews and affected persons have been notified.
- 2. If the person in charge of the shift is not on the surface, the foreman shall assume temporary charge of the operation and begin immediate implementation of the mine emergency responsibilities plan.
- 3. Assign a guard(s) at the mine portals to check all persons in and out of the mine. (A written log shall be kept.)
- 4. Assign an attendant(s) at the fan to ensure that the fan is operational, and take gas readings for carbon monoxide and methane (a written log shall be kept). If the fan was stopped, it shall not be restarted without authorization from the official in charge.
- 5. Assign the bathhouse man to make a positive, written accounting of all persons on shift who check out of the mine.
- 6. Assign a competent person to log conversations on the mine phone, and assist the monitor operator with his/her duties.
- 7. Assign persons to ready emergency materials, including the foam generator and fire trailer for transport underground.
- 8. Secure all accessible entrances to the mine property to prevent entrance of unauthorized personnel.
- 9. Organize a crew to load and deliver all needed supplies to the mine.
- 10. Assemble and load on supply trucks all emergency materials. The following materials should be promptly assembled (these are in addition to the mine emergency package maintained at the mine):
  - a. 40 pieces of 2-in by 4-in lumber in lengths of 8 to 16 ft
  - b. 5,000 board ft of brattice board
  - c. 200 cap pieces and 200 wedges
  - d. 1,000 concrete blocks
  - e. 12 bags of mortar mix
  - f. 15 packages of rigipak

- 11. In addition to these supplies, other materials such as timber, crossbars, additional cap pieces and wedges, cement blocks, etc., should be located and prepared to be sent underground as needed.
- 12. Arrange for the scheduling of persons under his/her supervision to provide for uninterrupted coverage during the emergency.
- 13. Arrange for persons from other mines for possible backup duty.
- 14. Keep surface area clear of all unnecessary equipment or vehicles.

#### MINE WAREHOUSE SUPERVISOR OR WAREHOUSEMAN

- 1. Proceed immediately to the mine monitor room, assist with notification of underground personnel if needed.
- 2. Shall be responsible to make immediate off-site notification by phone of the following persons (if not on shift):
  - a. Mine Manager
  - b. Chief Mine Safety Engineer
  - c. Mine Superintendent
  - d. General Mine Foreman
  - e. Maintenance Superintendent
  - f. Senior Mine Engineer
  - g. Warehouse Supervisor
  - h. Mine Clerk

A written log of persons contacted shall be kept.

- 3. Prepare any emergency kits, such as fire boxes, which are stored in the warehouse, for immediate transport underground.
- 4. Make provisions for the immediate use of the following: nails, brattice, hammers, axes, saws, picks, scaling bars, shovels, spad guns and spads and washers, fire extinguishers, rock dust, fire hose, rigipaks, telephones, phone wire, and hangers. For persons authorized by mine management, also arrange for coveralls, boots, gloves, hard hats, belts, and other safety equipment.
- 5. Keep a record of all equipment issued and returned.
- 6. Have assembled materials to be sent to the fresh air base for rescue workers, such as drinking water, Gatorade, first-aid supplies, wet gear, etc.

- 7. Arrange for uninterrupted coverage in the warehouse.
- 8. Coordinate activities with Central Warehouse and Central Purchasing.
- 9. Order adequate supplies and equipment for use during the emergency.
- 10. Coordinate materials to be delivered with the surface foreman, Central Warehouse, and purchasing. Notify the person in charge when needed materials are sent underground.

## EMERGENCY RESPONSE (FIRE DETECTION FOR TWO-ENTRY SYSTEM)

The development of two-entry longwall systems will be done under the stipulations pertaining to the Decision and Order for Petition for Modification, Docket No. 86-MSA-3, and outlined as follows:

- I. Development of the Two-Entry System
  - (a) An early-warning fire detection system utilizing low-level carbon monoxide detectors shall be installed in the panel intake escapeway entry and the panel belt entry used as a return air course as follow
    - (1) At the mouth of the panel in the intake escapeway entry, at the beginning of the working section, and at intervals not to exceed 1,000 ft along the panel intake escapeway entry.
    - (2) At the mouth of the panel in the return/belt conveyor entry, not more than 50 ft outby the section belt tailpiece, at intervals not to exceed 1,000 ft along the panel return/belt conveyor entry, and at each belt drive, except as provided in paragraph III(1).
  - (b) In addition to the carbon monoxide monitoring devices installed in the belt haulage entry, approved methane monitors shall be installed as follows:
    - (1) Approved methane monitoring devices shall be installed to monitor the return air in each belt haulage entry. Such devices shall be located so that the return air is monitored near the mouth of the longwall section, near the tailpiece of the belt conveyor, and at or near any secondary belt drive unit installed in the belt haulage entry.
    - (2) The methane monitoring devices shall be capable of providing both audible and visual alarm signals on both the working section and at a location on the surface where personnel will be on duty at all times when miners are underground and have two-way communication with all working sections. When the level of methane equals or exceeds 1.0 volume per centum, the device shall initiate alarm signals and shall deenergize the belt conveyor drive units and the equipment located on the section.
    - (3) The methane monitoring devices shall be visually examined at least once every 24 hr to ensure proper functioning. The unit shall be inspected by a person qualified for such work at intervals not exceeding 7 days. The qualified person shall ensure that the monitor is operating properly and that the required maintenance as recommended by the manufacturer is performed. The monitor shall be calibrated with known quantities of methane-air mixtures at intervals not exceeding 30 calendar days. An inspection record shall be maintained on the surface and made available to all interested persons. The inspection record shall show the date and time of each weekly inspection and calibration of the monitor and all maintenance performed.

#### II. Retreat Mining in the Two-Entry System

- (a) An early warning fire detection system meeting the following requirements shall be installed as follows:
  - (1) A low-level carbon monoxide detection system shall be installed in the belt entries utilized as intake air courses.
  - (2) The carbon monoxide monitoring devices in the intake entries shall be located so that the air is monitored at each belt drive and tailpiece and at intervals not to exceed 1,000 ft in each conveyor belt entry, except as provided in paragraphs II(a)(3) and III(1). The monitoring device located at the tailpiece shall be at the tailpiece or not more than 50 ft inby the tailpiece on the same split of air.
  - (3) Where a belt drive discharges onto a belt conveyor tailpiece in the intake entries as a continuation of a belt conveyor haulage system without a change of direction of the belt conveyor and the belt conveyor drive, belt take-up, and belt conveyor tailpiece are on the same split of air traveling in the same direction, only one low-level carbon monoxide sensor is required. It shall be installed not more than 100 ft inby the drive, belt take-up, and tailpiece on the same split of air.
- (b) A low-level carbon monoxide detection system shall be installed in the panel intake escapeway entry at the mouth of the panel in the intake escapeway entry, at the beginning of the working section, and at intervals not to exceed 1,000 ft in the panel intake escapeway entry.
- (c) During retreat mining, two separate and distinct intake air courses shall be provided from the beginning of each longwall panel to the face.
- III. Requirements Applicable to Both Development and Retreat Mining Systems
  - (a) The velocity of air in the belt conveyor entry shall be 50 ft/min or greater and shall have definite and distinct movement in the designated direction. The intake air-velocity measuring station at the two-entry section neck shall activate an alarm in the manned center on the surface and on the working section when the normal section intake velocity falls to 80 ft/min or less. Upon installation of the full monitoring system, the intake air velocity measuring station shall activate the alarm when the normal intake air quantity is reduced by 9,000 ft<sup>3</sup>/min or more.
  - (b) The low-level carbon monoxide system shall be capable of giving warning of a fire for a minimum of 4 hr after the source of power to the belt is removed during a fan stoppage or when the belt haulageway is examined, as provided in 30 CFR 75.1103-4(e)(1) and (e)(2).
  - (c) Interim alert and alarm signal levels and administrative controls approved by the District Manager shall be established for the low-level carbon monoxide monitoring system and the operations of the diesel equipment to provide early warning of fire. The warning time provided by the system shall be maximized. Once permanently established, the Ventilation System and Methane and Dust Control Plan required by 30 CFR 75.370 shall state the established alert and alarm signal levels and all administrative

controls necessary due to the operation of the diesel equipment.

The levels established shall be as follows:

In all belt entries, the maximum alert level shall be 20 ppm and the maximum alarm level shall be 30 ppi

In all locations other than belt entries, the maximum alert level shall be 25 ppm and the maximum alarm level shall be 30 ppm.

(1) Methods for establishing the alert and alarm signal levels for the low-level carbon monoxide monitoring system shall include continuous recording of carbon monoxide levels measured by all sensors in order to establish a mine history for carbon monoxide.

Time delays may be incorporated as necessary, with the maximum allowable delays as follows:

When a CO sensor reaches the low-level alert concentration, there may be a maximum of 45 sec delay time before the alert signal is activated in the control room. The operator shall immediately contact persons inby the sensor in alert and initiate an immediate investigation of the cause of the alert. During investigation of a low-level alert, all persons in the affected area shall be notified and a person shall man the phone continuously until the cause of the alert has been investigated. If no report is received from persons making the investigation within 15 min or if an additional sensor goes into alert, the visual alert on the section will be activated and all persons inby the sensor in alert shall withdraw to a safe location outby the working places. The procedures contained within this paragraph do not apply to the known nonhazardous alerts and alarms mentioned below.

If communications cannot be made or are lost, the visual alert on the section shall be immediately activated and all persons withdrawn to a safe location where communications can be established.

When a sensor reaches the high alarm level, the audible alarm on the affected section will be activated, communications shall be established, all persons shall be withdrawn outby the sensor in alarm, and the cause of the alarm shall be immediately investigated. If a hazardous condition is found and cannot be immediately controlled, the mine-wide firefighting and evacuation plan shall be implemented.

Known nonhazardous alerts and alarms caused by activities such as cutting, welding, blasting, and use of diesel to move heavy equipment other than normal daily diesel operation will not require the operator to withdraw persons inby that location provided prior notification is made by the person(s) at the source of the alarm and communications are maintained with that person throughout the duration of the alarm. The control room operator shall be notified when known nonhazardous alert and/or alarm activities have ceased. Should the concentration of CO reach the threshold limit value (TLV) of 50 ppm in the atmosphere of any work area, all affected persons shall be withdrawn.

(2) Administrative controls shall be used to minimize the number and type of pieces of diesel equipment in the two-entry system, to notify miners on the working section when any diesel equipment is operating in the

two-entry system, and to avoid alert and alarm signals caused by operating diesel equipment.

- (3) Diesel equipment shall not be used for face haulage equipment on the working section, except that diesels may be used on the working section for cleanup or similar noncoal haulage purposes.
- (4) No later than 2 years from the date of this Order and pursuant to a schedule developed by the petitioner and approved by the District Manager, all diesel-powered equipment operated on any two-entry longwall development or two-entry longwall panel shall be equipment-approved under 30 CFR 36.
- (5) All diesel-powered equipment operated on any longwall development or longwall panel shall be provided with a fire suppression system.
  - (d) The low-level carbon monoxide devices shall provide both visual and audible signals on the working section and at a manned surface location. A visual alert signal shall be activated when the carbon monoxide level at any sensor reaches a level established in accordance with paragraph III(c) for the mine, and an audible alarm signal shall be activated when the carbon monoxide level reaches a level established in accordance with paragraph III(c) for the mine. When the carbon monoxide system gives a visual alert signal, all persons shall be withdrawn to a safe area outby the working places, and appropriate action shall be taken to determine the cause of the signal. When the carbon monoxide system gives an audible alarm signal, the mine evacuation plan required by 30 CFR 75.1101-23(a) shall be implemented.
  - (e) When miners are underground, a responsible person shall be on duty at all times at a surface location to see the visual alert and hear the alarm signals of the carbon monoxide monitoring system when the carbon monoxide reaches the levels established in paragraph III(c). This person shall have two-way communications with all working sections. When the established alert and alarm signal levels are reached, the person shall notify all working sections and other personnel who may be endangered. The person shall be trained in the operation of the carbon monoxide monitoring system and in the proper procedures to follow in the event of an emergency or malfunction and, in that event, shall take appropriate action immediately.
  - (f) The carbon monoxide monitoring system shall be capable of detecting electrical malfunctions, such as electrical short circuits, open circuits, and ground faults and, where appropriate, pneumatic malfunctions in the system.
  - (g) The carbon monoxide monitoring system shall be capable of identifying any activated sensor. A map or schematic identifying each belt flight and the details for the monitoring system shall be posted at the mine.
  - (h) The carbon monoxide monitoring system shall be examined visually at least once each coalproducing shift and tested for functional operation at intervals not exceeding 7 days to ensure that the monitoring system is functioning properly and that required maintenance is being performed. The monitoring system shall be calibrated with known concentrations of carbon monoxide and air

mixtures at intervals not exceeding 30 calendar days. A record of all inspections shall be maintained on the surface and made available to all interested persons. The inspection record shall show the time and date of each weekly inspection, monthly calibration, and all maintenance performed on the system.

- (i) If at any time the carbon monoxide monitoring system or methane monitoring system or any portion of these systems required by this petition have been deenergized for reasons such as routine maintenance or failure of a sensor unit, the belt conveyor may continue to operate provided the affected portion of the belt conveyor entry is continuously patrolled and monitored for carbon monoxide and methane by a qualified person in the following manner until the monitoring system is returned to normal operation.
  - (1) If one sensor becomes inoperative, a qualified person shall monitor at that location.
  - (2) If two or more adjacent sensors become inoperative, a qualified person shall patrol and monitor the area affected; and
  - (3) If the complete system becomes inoperative, a sufficient number of qualified persons shall patrol and monitor the belt entries of the mine so that the belt haulage entries will be traveled each hour in their entirety or qualified persons shall be located at the end of each belt conveyor flight and monitor for carbon monoxide and methane.

Each of these qualified persons shall be provided with a handheld carbon monoxide detection device and methane detection device. A carbon monoxide detection device and methane detection device shall also be available for use of each working section in the event either monitoring system is deenergized or fails.

Monitoring with handheld instruments shall not be used in lieu of installation and use of the fire detection and methane monitoring systems described in this Order.

- (j) The carbon monoxide monitoring system located in the intake escapeway shall be patrolled and monitored in the same manner as described in paragraph III(I) if the system has been deenergized for reasons such as routine maintenance or failure of a sensor unit.
- (k) MSHA is in the process of developing new conveyor belt flammability testing procedures. Once these procedures have been developed, belting acquired for replacement and extensions of the conveyor belt system shall be belting identified by the new test procedures as meeting improved flame-resistant requirements.
- (1) The details for the fire detection system and methane monitoring system, including the type of monitor and specific sensor location on the mine map, shall be included as a part of the Ventilation System and Methane and Dust Control Plan required by 30 CFR 75.370. The District Manager may require additional carbon monoxide monitors and methane monitors to be installed as part of said plan to ensure the safety of the miners.
- (m) The concentrations of respirable dust in the intake air in the belt conveyor entries used as intake air courses shall comply with the requirements of 30 CFR 70.100(b). Respirable dust samples shall be taken in all belt entries used as intake aircourses, and the location of the sampling areas shall be included as designated areas in the Ventilation System and Methane and Dust Control Plan.
- (n) Mantrip cars or personnel carriers or other transportation equipment shall be maintained on or near the working section and shall be of sufficient capacity to transport all persons who may be in the
area.

- (o) During development of the two-entry panel, a rock dusting unit shall be installed in the belt conveyor entry near the section loading point. Also, during longwall retreat mining in the two-entry panel, a rock dusting unit shall be installed on or near the last tailgate shield. These rock dusting units shall run continuously during mining operations to render inert float coal dust in these entries except when miners are performing maintenance, inspections, or other required work in these areas.
- (p) Diesel fuel shall not be stored in the two-entry panel.
- (q) Fire doors designed to quickly isolate the working sections shall be constructed in the two entries for potential use in emergency situations. Miners working in the two-entry panel shall be trained in the use of the fire doors.
- (r) The hydraulic fluid pump station for the longwall support system shall not be located in the twoentry panel and shall comply with the provisions of 30 CFR 75.345.
- (s) The permanent stoppings separating the conveyor belt entries from the intake escapeway shall be constructed of solid concrete blocks. The stoppings shall be installed with mortared joints or coated with a sealant that provides equivalent strength to a mortared joint installation. Overcasts shall be constructed of concrete block with concrete and rail or I-beam construction. No ventilation structures shall be constructed of aluminum.
- (t) A safe travelway shall be maintained for each longwall panel through the tailgate side of the longwall in accordance with 30 CFR 75.215 and 75.222. MSHA shall be notified immediately if a roof fall occurs that impedes travel in a tailgate travelway or if a travelway otherwise becomes unsafe for travel. A weekly examination of tailgate travelways shall be conducted by a qualified person and the results recorded.
- (u) Two separate communication lines shall be maintained. One shall be located in each of the two entries during development.
- (v) At least one self-contained self-rescuer shall be available for each person on the working section and shall be stored on the section while advancing the two-entry panel. During longwall retreat mining, self-contained self-rescuer units shall be stored near the face on the headgate and tailgate sides of the longwall unit at readily accessible locations. Sufficient self-contained self-rescuer units for all miners on the working section shall be stored at both locations. These locations shall be specified in the storage plan approved by the District Manager.

## FIREFIGHTING AND EVACUATION PLAN

#### 75.1101-23

Firefighting and Evacuation Plans at the Mine will consist of a program of instruction, location, and use of firefighting equipment, location of escapeways, exits and routes of travel, evacuation procedures, and fire drills, which will involve all employees.

- 1. All new employees undergoing orientation classes at the mine site are instructed during their underground training session on the use and locations of fire suppression equipment in the working sections, location of escapeway exits, routes of travel, evacuation procedure, and fire drills.
- 2. All employees will receive instruction on location and use of communications systems.
- 3. All miners will participate in a fire drill at intervals of not more than 90 days using attached procedures as guidelines.
- 4. A firefighting and evacuation program will be available on each section, which will include delegations of specific persons and responsibilities.
- 5. A written record shall be kept in a Fire Drill Record Book, to be located in the Safety Supervisor's offic
- 6. If the automatic belt fire warning system alarms, the location indicated on the monitor will be investigated immediately. If conditions are found to warrant evacuation, the firefighting plan will be implemented.
- 7. On units that incorporate intake/belt air, when the carbon monoxide system gives an alert or alarm signal, the following shall be followed:
  - a. Alert Level: When the carbon monoxide monitoring system gives a visual or audible alert signal, all miners in the working sections on the same split of air shall be notified immediately, and an investigation shall be conducted to determine the cause of the actuation.
  - b. Alarm Level: When the carbon monoxide system gives an audible and visual alarm signal, all miners in the same split(s) of air shall be withdrawn immediately to a safe location at least one sensor outby the sensor(s) activating the alarm, unless the cause is known not to be a hazard to the miners. When the carbon monoxide warning system gives an audible and visual alarm signal at shift change, no one shall be permitted to enter the mine except qualified persons designated to investigate the source of the alarm. If miners are en route underground, they shall be held at, or be withdrawn to, a safe location at least one sensor outby the sensor(s) activating the alarm. When a determination is made as to the source of the alarm and that the mine is safe to enter, the miners shall be permitted underground.
  - c. When the established carbon monoxide alert and alarm levels are reached, all working sections and other locations where personnel are normally assigned to work (e.g., belt transfers) will be notified.

In steps a, b, and c above, if it is determined that a fire exists and the fire is not extinguished within 15 min of discovery, all persons not required for firefighting activities shall be evacuated from the mine immed

8. When the carbon monoxide warning system gives an audible and visual alarm signal at shift charge, no one shall be permitted to enter the mine except qualified persons designated to investigate the source of the alarm. If miners are en route underground, they shall be held at, or be withdrawn to, a safe location at least one sensor outby the sensor(s) activating the alarm. When a determination is made as to the source of the alarm and that the mine is safe to enter, the miners shall be permitted underground.

#### Procedure in Case of Fire Outby Sections

- 1. Directly attack fire.
- 2. Call Warehouse to report fire:
  - a. Give your name
  - b. Location calling from
  - c. Location of fire
- 3. Warehouse will then:
  - a. Notify Shift Mine Manager or other appropriate personnel and shut off all belts.
  - b. Notify all areas inby the fire to immediately remove all personnel to a location outby the fire, or to a safe location at least one carbon monoxide sensor outby the carbon monoxide sensor(s) activating the alarm (if applicable).
  - c. Alert all other sections of location of fire and direct supervisors of those sections to standby telephone and be prepared to take additional firefighting equipment to fire or to evacuate mine.
  - d. Notify Mine Manager, General Mine Foreman, and Supervisor of Safety.
- 4. Establish ventilation to direct smoke directly to a return and keep fresh air to persons fighting the fire.
- 5. Call for additional firefighting equipment if needed. Direct this request to the Warehouse.
- 6. If fire is not extinguished within 15 min of discovery, all persons not required for firefighting activities will be removed from the mine.
- 7. After evacuation is completed, Shift Mine Manager will check or have checked, the check-in board to see that all tags are removed, and that all personnel not involved in the firefighting activity are out of the mine.

#### Procedure in Case of Fire on Continuous Miner Section

Order of Leadership	Duties To Perform
1. Foreman	Supervise the operation.
2. Mechanic	Shut power off, get tools ready; assist with getting extra hose and other firefighting equipment, if needed.
3. Miner Operator	Water hose off miner.
4. Miner Operator	Operate water valve, get extra hose from emergency sled.
5. Coal Hauler #1 Operator	Fire extinguishers.
6. Coal Hauler #2 Operator	Fire extinguishers.
7. Coal Hauler #3 Operator	Ventilation and rock dust; get Vari-X foam concentrate from sled and operate the eductor.
8. Roof Bolter #1	Phone attendant.
9. Roof Bolter #2	Ventilation; get Vari-X from sled and operate Vari-X.
10. Utilityman	Rock dust.

- 1. Directly attack fire.
- 2. Pull power at transformer.
- 3. Remove all persons from inby fire.
- 4. Call Warehouse and report fire.

Warehouse will then:

- a. Notify Shift Mine Manager or other appropriate personnel and shut off all belts.
- b. Alert all underground sections of location of fire.
- c. Notify Mine Manager, General Mine Foreman, and Supervisor of Safety.
- 5. Establish ventilation to keep fresh air to persons fighting fire and direct smoke to return.
- 6. Call for additional firefighting equipment: material, cars, rock dust, etc.
- 7. If fire is not extinguished within 15 min of discovery, all personnel not required for firefighting will be removed from the mine. Shift Mine Manager will direct evacuation of mine.
- 8. After evacuation is completed, Shift Mine Manager will check, or have checked, the check-in board to see that all tags are removed and that all personnel not engaged in the firefighting activity are out of the r

#### Procedure in Case of Fire on Section

Order of Leadership		Duties To Perform	
1. Foreman		Supervise the operation.	
2. Mechanic		Shut power off, get tools ready; assist with getting extra hose and other firefighting equipment if needed (e.g., Vari-X).	
3. Technician		Phone attendant.	
4. Roof Bolter #1		Operate water valve, get extra hose, if needed.	
5. Roof Bolter #2		Fire extinguishers and fire hose.	
6. Mini Scoop Operat	or	Fire extinguishers and fire hose.	
7. Remote Scoop Ope	erator	Get rock dust and change ventilation, if needed.	

- 1. Directly attack fire.
- 2. Pull power at transformer.
- 3. Remove all persons from inby fire.
- 4. Call Warehouse and report fire.

Warehouse will then:

- a. Notify Shift Mine Manager or other appropriate personnel and shut off belts.
- b. Alert all underground sections of location of fire.
- c. Notify Mine Manager, General Mine Foreman, and Supervisor of Safety.
- 5. Establish ventilation to keep fresh air to persons fighting fire and direct smoke to return.
- 6. Call for additional firefighting equipment: material, cars, rock dust, etc.

- 7. If fire is not extinguished within 15 min of discovery, all personnel not required for firefighting will be removed from the mine. Shift Mine Manager will direct evacuation of mine.
- 8. Diesel foam generator may be used to indirectly attack the fire.
- 9. After evacuation is completed, the Shift Mine Manager will check, or have checked, the check-in board to see that all tags are removed and that all personnel not engaged in the firefighting activity are out of the mine.

#### Procedure for Evacuation on Continuous Miner Section

Order of Leadership	Duties To Perform	
Foreman	Direct the procedure. First-aid kit and escape map.	
Mechanic	Shut off power and take nails, hammer, and spads, etc.	
Miner Operator	Saw, pick, and shovel.	
Miner Operator Helper	Sledge hammer and extra SCSRs.	
Roof Bolters	Spads, nails, brattice cloth.	
Coal Hauler Operators	Get all lunch buckets and clothing from dinner hole.	
Utilityman	Brattice cloth and first-aid equipment.	

Know Your Escape Routes:

- 1. Account for all of the personnel on the section.
- 2. Be sure that each miner has a self-rescuer, and take all the extra rescuers with you.
- 3. Explain the escape route to the entire crew. Direct air to return not designated as alternate escapeway. Attempt to travel the primary escapeway. If smoke is encountered, proceed to the alternate escapeway. The foreman will lead the group with second-in-command bringing up rear to prevent stragglers.
- 4. Move fast, but do not run. At frequent intervals, check the mandoors to see if you are past the fire area. When past the fire area, you may travel in either escapeway and continue exiting the mine.

#### Procedure for Evacuation on CM Section

Order of Leadership	Duties To Perform	
Foreman	Direct the procedure. First-aid kit and escape map.	
Mechanic	Shut off power and take nails, hammer, and spads, etc	
Technician	Saw, pick, shovel, and sledge hammer.	
Roof Bolter #1	Spads, nails, and brattice cloth.	
Roof Bolter #2	Get extra SCSRs.	
Mini Scoop Operator	Get all lunch buckets and clothing from dinner hole.	
Remote Scoop Operator	Brattice cloth and first-aid equipment.	

Know Your Escape Routes:

- 1. Account for all of the personnel on the section.
- 2. Be sure that each miner has a self-rescuer, and take all the extra rescuers with you.
- 3. Explain the escape route to the entire crew. Direct air to return not designated as alternate escapeway. Attempt to travel the primary escapeway. If smoke is encountered, proceed to the alternate escapeway. The foreman will lead the group with second-in-command bringing up rear to prevent stragglers.
- 4. Move fast, but do not run. At frequent intervals, check the mandoors to see if you are past the fire area. When past the fire area, you may travel in either escapeway and continue exiting the mine.

## FIREFIGHTING AND EVACUATION DUTIES

#### Precautions:

In the event that a miner should smell smoke, sees a fire, or possibly identifies a fire prior to an alarm, the miner will communicate this immediately and follow the Firefighting and Evacuation Plan.

Firefighting Duties:

Each miner will be instructed in the following firefighting duties:

- I. Continuous Miner Sections (Production)
  - a. Section Foreman
    - 1. The foreman is responsible for all firefighting evacuation and communication procedures.
    - 2. The section power and equipment are to be secured.
    - 3. Section ventilation changes are to be directed by the foreman.
    - 4. Assembly of miners for evacuation is to be directed by the foreman.
  - b. Miner Operator

If the fire is on the miner:

- 1. Deenergize the miner (on board).
- 2. Activate the fire suppression.
- 3. Locate and use appropriate firefighting equipment.
- c. Miner Helper

If the fire is on the miner:

- 1. Deenergize the trailing cable.
- 2. Notify the foreman.
- 3. Locate and use appropriate firefighting equipment.

If the fire is on the section, the miner operator and helper are to:

- 1. Secure the miner.
- 2. Deenergize the trailing cable.
- 3. Disconnect the miner water hose, attach fire nozzle, and await firefighting instructions.

d. Shuttle Car Operations

If the fire is on the shuttle car:

- 1. Set the brakes.
- 2. Deenergize the on-board power.
- 3. Activate the fire suppression.
- 4. Deenergize the trailing cable.
- 5. Locate and use appropriate firefighting equipment.
- 6. Notify the foreman.

If the fire is on the section:

- 1. Secure the car.
- 2. Deenergize the trailing cable.
- 3. Locate appropriate firefighting equipment to assist in firefighting and assemble at the crew stati-
- e. Roof Bolter

If the fire is on the roof bolter:

- 1. Deenergize the bolter (on board).
- 2. Activate the fire suppression.
- 3. Locate and use appropriate firefighting equipment.
- f. Roof Bolter Helper

If the fire is on the bolter:

- 1. Deenergize the trailing cable.
- 2. Notify the foreman.
- 3. Locate and use appropriate firefighting equipment.

If the fire is on the section, the roof bolter and helper are to:

- 1. Secure the bolter.
- 2. Locate appropriate firefighting equipment to assist in firefighting and assemble at the crewstatic

#### g. Bratticeman

If the fire is on the section:

- 1. Locate appropriate firefighting equipment and assemble at the crewstation.
- 2. Notify and assemble any nonproduction miners on the section.

#### h. Mechanic

If the fire is on the section:

- 1. Assemble appropriate firefighting equipment.
- 2. Determine that section power is secured.
- 3. Assist the foreman as directed.
- i. Material Man

If the fire is on the section:

- 1. Start and prepare the mantrip for evacuation.
- 2. Assemble SCSR units in storage for use.
- 3. Establish communications with the surface, shift foreman, or designated person in charge.

If the fire is not on the section:

- 1. Notify the section foreman of the fire.
- 2. Establish communications with the surface.
- 3. All face personnel are to assemble at the crewstation.
- 4. All persons are to evacuate the mine or follow firefighting instructions from the shift foreman or designated person in charge.

#### II. Continuous Miner Section (Maintenance Shift)

- a. Maintenance Foreman
  - 1. The foreman is responsible for all firefighting and evacuation procedures.
  - 2. The section power and equipment are to be secured.
  - 3. Section ventilation changes are to be directed by the foreman.
  - 4. Assembly of miners for evacuation is to be directed by the foreman.

b. Mechanics

If the fire is on equipment being serviced or repaired or on service equipment:

- 1. Deenergize the machine (on board).
- 2. Activate the fire suppression.
- 3. Deenergize the trailing cable.
- 4. Locate and use appropriate firefighting equipment.
- 5. Notify the foreman.
- III. Longwall Section (Production)
  - a. Section Foreman
    - 1. The foreman is responsible for all firefighting and evacuation procedures.
    - 2. The section power and equipment are to be secured.
    - 3. Section ventilation changes are to be directed by the foreman.
    - 4. Assembly of miners for evacuation is to be directed by the foreman.
  - b. Shear Operators

If the fire is on the shear:

- 1. Deenergize the shear (on board).
- 2. Activate the suppression.
- 3. Notify the foreman.
- 4. Locate and use appropriate firefighting equipment.

If the fire is on the face:

- 1. Notify the foreman.
- 2. Leave shear sprays on.
- 3. Activate and use an SCSR unit.
- 4. Move to the stageloader and assemble at the crewstation.
- c. Shield Operators

If the fire is inby:

- 1. Move to the crewstation.
- 2. Obtain appropriate firefighting equipment to assist in firefighting.
- 3. Await instructions.

If the fire is outby:

- 1. Notify the foreman.
- 2. Activate and use an SCSR unit.
- 3. Move to the stageloader and outby to the crewstation.
- 4. Locate and use appropriate firefighting equipment.
- d. Headgate Operator
  - 1. Deenergize the longwall at the stageloader.
  - 2. Notify the foreman and crew.
  - 3. Use a fire extinguisher on a stageloader fire.
  - 4. Establish communications with the surface.
  - 5. Notify the shift foreman or person in charge.
  - 6. Remain in contact with the surface.
  - 7. Relay information about the fire.
- e. Mechanic
  - 1. Disconnect power at power center.
  - 2. Locate all available fire extinguishers and move them to the stageloader.
- f. Utilityman
  - 1. Start and prepare the mantrip for evacuation.
  - 2. Assemble SCSR units in storage for use.
  - 3. Notify and assemble any nonproduction miners on the section.

#### IV. Outby Areas

- a. Use any firefighting equipment that is readily available.
- b. Disconnect power from the affected area or equipment.
- c. Notify the surface of the fire and conditions.
- d. Obtain additional firefighting equipment for use on the fire.

#### V. Shift Foremen

- a. Evacuate all miners not required for firefighting.
- b. Coordinate and dispatch personnel and equipment for firefighting.
- c. Implement the Notification Plan.
- d. Account for the location of all miners on shift.

Firefighting and Mine Rescue Mobilization:

Mine rescue and/or firefighting crews will be notified by pager or telephone, as appropriate, and will be assembled at the mine rescue station.

Diesel mantrips and other diesel equipment that might be available will be assembled at the bathhouse area to be used as transportation of mine rescue crews, rescue apparatus, firefighting crews, and fire suppression equipmen

All firefighting operations shall be conducted from the fresh air side of a fire.

Mine rescue teams will not operate inby a fire without specific permission of the mine emergency controll

Self-Rescuer Program of Instruction:

The Program of Instruction will be presented to all experienced miners at least annually and will be included as part of the 8-hr annual training program required by 30 CFR 48.8(a).

The Program of Instruction will be presented to newly hired miners and will be presented as part of the training required for inexperienced miners and newly hired experienced miners prior to assigning them to work duti

Self-Contained Self-Rescuer:

The recommended "hands-on" training method will be used to train miners on the SCSR units.

## PROCEDURE AND DUTIES FOR FIRE

To follow up on the recent training you received on the Vari-X foam generator, the following procedures have been developed to communicate to all employees their responsibilities in the event of a fire on a section.

ORDER OF LEADERSHIP	DUTIES TO PERFORM
1. Foreman	Supervise the operation.
2. Mechanic	Shut off power, get tools ready.
3. Miner Operator	Water-hose off miner.
4. Miner Operator	Operate water valve, get extra hose from emergency sled.
5. Coal Hauler #1 Operator	Fire extinguishers.
6. Coal Hauler #2 Operator	Fire extinguishers.
7. Coal Hauler #3 Operator	Ventilation and rock dust; get Vari-X foam concentrate from sled and operate the eductor.
8. Roof Bolter #1	Phone attendant.
9. Roof Bolter #2	Ventilation/get Vari-X from sled and operate Vari-X.
10. Utilityman	Rock dust.

1. Directly attack fire.

- 2. Pull power at transformer.
- 3. Remove all persons from inby fire.
- 4. Call Communications Center/Warehouse and report fire. Communication Center/Warehouse will:
  - a. Alert all underground sections of location of fire.
  - b. Notify Mine Manager, Mine Superintendent, and Health & Safety Supervisor.
  - c. Notify Shift Supervisor to alert idle crews not working on the section of the fire.
- 5. Establish ventilation to keep fresh air to persons fighting fire, and direct smoke to return.

NOTE: All fire hose outlets are equipped with an adapter to allow attachment of a 1.5-in fire hose. Extra

adapters are located in the bottom of each fire hose barrel and on the emergency sled should one of the outlet adapters be damaged.

#### SPECIFIC INDIVIDUAL DUTY LABELS IN THE EVENT OF A FIRE

# In case of FIRE ON THE SECTION

REPAIRMANCall communications
MINER OPERATORShut off section power
MINER HELPERWater hose and rock dust
SCOOP OPERATORWater hose and rock dust
UTILITYMANWater hose and rock dust
ROOF BOLTERSFire extinguishers
SHUTTLE CAR OP'SAssist as directed
SECTION FOREMANDirect firefighting

Report Status of Fire to Communications Coordinator Every 10 Minutes. If Fire is Not Under Control in 15 Minutes, Evacuate the Section!

# WHEN ESCAPE IS CUT OFF

#### 1. BARRICADE

2. LISTEN for 3 shots, then...

3. SIGNAL by pounding hard 10 times

4. **REST** 15 min, then **REPEAT** signal until...

5. **YOU HEAR 5 SHOTS,** which means you are located and help is on the way.

#### LONGWALL FIREFIGHTING PLAN IN THE EVENT OF A FIRE, THE LISTED PEOPLE WILL ASSUME THE FOLLOWING DUTIES

Longwall repairman: Deenergize all power, then proceed to

the telephone and coordinate all phone messages.

Other personnel on section: Assemble at fire skid. Operators: Begin laying 1-3/4-in hose to fire areas. Utilitymen: Begin laying 5-in feeder hose to fire area.

Supervisor: Contact all employees and communications.

#### PROCEDURES

#### CHECK THAT:

- 1. All power has been removed.
- 2. Communications has been notified.
- 3. All personnel are assembled at the fire skid.
- 4. Notify Communications that all employees are accounted

for and action to be taken.

- 5. Advise employees of the plan of attack and firefighting.
- Report status of fire to Communication Coordinator every 10 min. If fire is not under control in 15 min,

evacuate the section.

#### MINE FIRE TRAINING PROGRAM

- 1. Mine fire training can be divided into the following three areas:
  - a. Basic training for all miners.
  - b. Intermediate training for mine fire brigades/mine rescue.
  - c. Advanced training for fire brigades/mine rescue.
- 2. The basic fire training for all miners may consist of the following and could be conducted aboveground:
  - a. Basic fire chemistry (classes of fires, fire triangle, smoke, heat).
  - b. Assessment of containability of fightable fires.
  - c. Types of portable fire extinguishers, hose lines, and water nozzles.
  - d. Extinguishing a liquid fuel and solid fuel fire with portable fire extinguishers.
  - e. Extinguishing a solid fuel fire with water lines.
  - f. Paper-and-pencil simulations on fighting a small mine fire.
  - g. Mine evacuation procedures.
  - h. Understanding the operation of fire sensors (thermal, smoke, CO).
- 3. Intermediate training for mine fire brigades/mine rescue basic fire training, plus the following:
  - a. Use of handheld and large foam generators.
  - b. Turnout gear and equipment used for firefighting.
  - c. Fighting fires in smoke, wearing SCBAs.
  - d. Paper-and-pencil simulations on fighting fires outby the section.
  - e. Firefighting strategies: underground fire houses, fire cars, or trailers.
- 4. Advanced firefighting training would include all of the skills acquired in the basic and intermediate levels, plus the following:
  - a. Combating simulated mine fires in ventilated entries with portable and wheeled fire extinguishers, water lines, and foam generators. The fires would include equipment fires, conveyor belt fires, etc.
  - b. Erecting seals to isolate fire areas.
  - c. Examining the effect of ventilation on fires and regulating air during a fire.

#### FIRE DRILL SIMULATIONS

Unannounced simulation fire drills were conducted. The drills were designed to test the response actions of production crew personnel, including the Section Foremen responding to a fire/smoke emergency. Since each unit has unique mining and ventilation systems, drill locations were selected based on greatest potential for occurrence. Each drill lasted approximately 15 to 20 min, and a critique was held immediately following the drill. These drills were conducted concurrent with MEO requirements designed to evaluate OIMS System 10-2 - Emergency Response. This memo includes a brief description of each simulation scenario and documents key recommendations made by observers and participants.

#### Drill Scenario Unit #3:

At 9:45 a.m., the Section Foreman observed smoke leaking through the flame-resistant isolation curtains located at the Unit Battery Charging Station. The smoke was contaminating entry No. 2, which is the intake airway for that section.

#### Summary of Key Response Activities:

Section Foreman:

- Notified Communications of situation and advised him to notify Fire Brigade.
- Advised Scoop Operator to deenergize unit power center.
- Notified crew members to evacuate face area and assemble outby smoke location.

#### Crew Members:

- Four members brought fire extinguishers to smoke location.
- One member ensured that incoming power cable was deenergized prior to entering fire location.
- Several crew members installed line brattice to short-circuit smoke to return airway.
- Several crew members obtained SCSRs from storage location at power center and carried them to the fire location.

#### Critique:

- The crew/FLS responded promptly and orderly, although one crew member was not aware of emergency situation.
- Many crew members were aware of the unit fire skid, but were not familiar with assembly procedures of the advanced firefighting equipment.
- One fire extinguisher brought to the fire location was in very poor condition (if even operable).

#### Drill Scenario Unit #2:

At 11:10 a.m., the Section Foreman discovered smoke on the inby end of the unit power center located in entry No. 5 several crosscuts outby the face area.

#### Summary of Key Response Activities:

Section Foreman:

- Notified Communications of the situation and advised him to notify the Fire Brigade.
- Notified section repairman to deenergize unit power center.
- Notified crew members to evacuate the face area via the intake escapeway to a location just outby the smoke area.
- Advised responding crew members to remove smoke by coursing fresh air from an adjacent intake airway using line brattice.

Crew Members:

- Several members brought fire extinguishers to the smoke location.
- One crew member obtained a roll of line brattice.
- One crew member brought pipe wrenches to break the water hose so that water would be available, if need
- Remaining crew members (less one who was not informed of the situation) assembled outby the fire area to assist the initial responders.

Critique:

- Crew members responded promptly and took immediate action.
- As stated above, one crew member was not informed of the situation.
- Crew members were not aware of unit fire skid location or assembly procedures required to use their advanced firefighting equipment stored on the skid.

#### Drill Scenario Unit #1:

At 12:15 p.m., the Section Foreman observed smoke entering the section from the No. 2 entry. Upon investigation, he discovered that the scoop tractor was on fire. The unit had just begun a power and belt retraction.

#### Summary of Key Response Activities:

Section Foreman:

- Notified Communications of the situation and advised him to assemble the Fire Brigade.
- Notified section repairman to deenergize the unit power center.
- Notified crew members to evacuate the face area via escape routes and to approach the fire area from fresh air (outby) side.

Crew Members:

- Three members obtained fire extinguishers from various locations and used them to extinguish the fire from the fresh air side.
- Three other members began laying fire hose to the fire location. Hose was obtained from the unit fire ski

- One non-crew member carried SCSRs from the headgate to the fire area.
- Remaining crew members assembled outby the fire location to form a labor pool.

#### Critique:

- Crew members responded promptly and took immediate action.
- Two surveyors working in the section were not notified of the emergency. After observing the crew members exiting the face area, they decided to investigate.
- Several crew members stated that had they been operating the longwall and working on the face under similar circumstances, they would evacuate via the tailgate escapeway. It was suggested that all crew members using this escape route notify Communications so that the Section Foreman and responding personnel were aware of their location.

#### Areas for Improvement

IMPROVEMENT ACTIVITIES	RESPONSIBILITY	TARGET DATE
Identify the best means to notify persons working the unit of an emergency.	ng in WTC	Month/year
Evaluate the current SCSR storage location in a units, and determine if a better location exists f each working section.	1 Safety Department	Month/year
Evaluate the current SCSR storage containers for the best possible protection from damage and/o contamination.	or Safety Department r	Month/year
Train all crew members on proper assembly procedures for advanced firefighting equipment stored in the unit fire skids.	Fire Brigade	Month/year
Conduct unannounced fire drills at least once po year.	er Safety Department/ Mine Superintendent	Begin during <i>month/year</i>

# SELECTION PROCEDURES FOR NEW EMERGENCY RESPONSE MEMBERS

- 1. Post notice on bulletin boards informing all employees of any vacancy.
  - C The vacancy notice will be posted by management in a conspicuous place at the mine for a period of 5 calendar days, but no less than 3 production days. All employees absent from work due to illness or other legitimate reasons during the posting period will be notified by management of the vacancy. An employee on leave of absence working for local, district, or International Union, if he/she so requests, shall be notified by management of the vacancy. The employer will, on the date of the posting, give notice to such employees of the vacancy by certified mail to their last known address. (This is the same as the contract job bidding procedures.)
  - C Vacancy notices will also be posted on the salaried bulletin boards located in foremen's conference room and in the mail room.
  - C All department heads and shift managers will be given copies of the notice of vacancy and will advise all minorities, women, and staff personnel of the vacancy. This will ensure that all affirmative action guidelines are met. Each manager will return to the Training Coordinator the list of minorities and/or staff personnel with the date that each employee was advised of said vacancy. This list shall be retained for the current year plus 2 years.
- 2. Notices should direct interested employee(s) to the Training Coordinator in charge of the emergency response teams.
- 3. The Training Coordinator will briefly explain what is expected of the particular emergency response team members. This should include, but is not limited to, physical expectations, training requirements, and member duties. At this time, the applicant will be given a questionnaire to complete and return to the Training Coordinator within a specified time.
- 4. Those employees still interested will be instructed to sign a registration form located in the Training Office. This list will be available for 2 weeks after notice of vacancy is taken down.
- 5. This list will be reviewed by the Human Resources Supervisor to determine if there are any applicants that are covered by the Americans with Disabilities Act. If so, the Human Resources Supervisor will advise the Training Coordinator.

- 6. After registration is closed, each interested employee will be interviewed for the position. Two interviewers will be present; one will be the Training Coordinator and another interviewer to be named.
- 7. The Accident and Absenteeism history will be pulled from the archives and will be reviewed and discussed with the individual. This history should be pulled for the current year plus 2 previous years.
- 8. Interviewer should tell in detail what the expectations are of the particular response team members. Also, the interviewer should ask what the applicant expects to get from being a response team member.
- 9. Applicants will be asked if they have any experience as firefighters, rescue team members, or members of any other emergency response teams.
- 10. The interviewers will use a summary form to rate the applicants. The name of the selected candidate shall be submitted to the Mine Superintendent for approval. The remaining pool or list of candidates will be retained for 1 year. Any vacancies that occur within this period will be filled from the applicants listed in this pool.

## **REQUIREMENTS FOR EMERGENCY RESPONSE TEAMS**

## INITIAL MEDICAL EVALUATION

Step 1 - Health Risk Assessment (HRA)

- C Required of all response team members.
- C Will be used for informational purposes only.

Step 2 - Health Risk Followup and Additional Testing

- C Present results of the Health Risk Assessment.
- C Complete the medical questionnaires.
- C Lab work blood and urinalysis.
- C Conduct pulmonary function.

Step 3 - Doctor's Examination

- C Continue to use the National Institute for Occupational Safety and Health form for mine rescue personnel
- C Perform the Step Test.
- C Recommend further evaluation(s) if indicated.
- C Stress test required if over age 45.
- C Complete Notification of Exam Results Memorandum.

#### PERIODIC MEDICAL EVALUATION

- C Minimum fitness requirements should be met at all times.
- C Same format as the initial evaluation, except no Health Risk Assessment.
- C Continue annual National Institute for Occupational Safety and Health exam for mine rescue team membe
- C Medical evaluation every 3 years if under age 45.
- C Evaluation every 2 years if age 45 or older.
- C Members will complete the cardiovascular risk analysis questionnaire in the off years.

#### TEAM MEMBER THAT FALLS SHORT OF MINIMUM STANDARD

C Notification of Exam Results Memorandum forwarded to employee and Health Risk Assessment (HRA)

- C HRA Team makes recommendation to Operations Superintendent.
- C Doctor must reexamine individual before he/she can reinstated on team or returned to normal duty.

# PROCEDURES FOR FIT TESTING EQUIPMENT

- C Annual fit test required for face masks.
- C Beard/facial hair
  - Fire Brigade members no beards allowed
  - Mine Rescue members must remove beards for annual fit testing and prior to emergency response.

#### TRAINING OF FIRE BRIGADE MEMBERS

Fire brigade members are trained in coal mine firefighting and coal mine fire prevention. In the event of a fire, their training skills will be utilized in controlling a fire. This training is done by the methods listed below:

- 1. Monthly meeting in which various techniques are practiced and discussed.
- 2. Outside experts are invited to lecture and train the fire brigade.
- 3. Certain members of fire brigade are chosen to attend training sessions provided by government agencies, schools, and fire services. These sessions usually include classroom lectures, discussion, and a liberal amount of "hands-on" training.

These new skills and techniques are then shared with the rest of the fire brigade and mine rescue team members. The members are asked to write a brief paper describing and explaining what they had seen, heard, and done.

#### FIRE BRIGADE MEMBERS TRAINING OTHER MINERS

Safety management here feels it is best to utilize fire brigade and mine rescue team members to train all employees in the areas of fire prevention, firefighting techniques, and firefighting equipment. Since we are trained in these areas on a regular basis, safety management feels that we are best equipped to share our knowledge and experience with our coworkers. At our annual refresher, we have been asked to be instructors on such items as the foam generator, handheld fire extinguisher, and hose and nozzle handling techniques.

## STANDARD OPERATING PROCEDURES FOR FIRE ATTACK OF THE FIRE BRIGADE

- 1. Contact Communication Coordinator
  - Arrival time
  - Brigade members on scene
  - Conditions upon arrival
  - Action to be taken
- 2. Establish command
  - Establish a fresh air base
  - Secure evacuation transportation
  - Form a plan of attack
  - Check equipment
  - Radio check
- 3. Execute attack
  - Rescue
  - Exposures
  - Confinement
  - Extinguish
  - Overhaul
- 4. Terminate incident

# DONNING PROCEDURES FOR PA-80 SCBA

- 1. Push demand regulator to donning mode.
- 2. Turn cylinder valve on and compare gauges.
- 3. Don the SCBA.
- 4. Don the face mask.
- 5. Insert the demand regulator in face mask.
- 6. Check positive pressure.
- 7. Check bypass function.
- 8. Check face mask seal. Shut cylinder valve off. Watch chest gauge fall to zero and listen for warning whistle.
- 9. Turn  $O_2$  valve back on and watch gauge.
- 10. Put Nomex hood over face mask.